

# AVERAGE DAILY UNIT POWER LEVEL

DOCKET NO. 50-313  
 UNIT 1  
 DATE 8/14/81  
 COMPLETED BY L. S. Bramlett  
 TELEPHONE (501) 968-2519

MONTH July

DAY	AVERAGE DAILY POWER LEVEL (MWe-Net)
1	<u>787</u>
2	<u>792</u>
3	<u>791</u>
4	<u>792</u>
5	<u>791</u>
6	<u>798</u>
7	<u>805</u>
8	<u>591</u>
9	<u>446</u>
10	<u>797</u>
11	<u>798</u>
12	<u>797</u>
13	<u>796</u>
14	<u>753</u>
15	<u>0</u>
16	<u>0</u>

DAY	AVERAGE DAILY POWER LEVEL (MWe-Net)
17	<u>0</u>
18	<u>0</u>
19	<u>0</u>
20	<u>0</u>
21	<u>0</u>
22	<u>0</u>
23	<u>0</u>
24	<u>0</u>
25	<u>0</u>
26	<u>0</u>
27	<u>1</u>
28	<u>468</u>
29	<u>757</u>
30	<u>804</u>
31	<u>804</u>

## INSTRUCTIONS

On this format, list the average daily unit power level in MWe-Net for each day in the reporting month. Compute to the nearest whole megawatt.

(9/77)

8211150652 810814  
 PDR ADOCK 05000313  
 R PDR

# OPERATING DATA REPORT

DOCKET NO. 50-313  
 DATE 08/14/81  
 COMPLETED BY L. S. Bramlett  
 TELEPHONE 501-968-2519

964-3145

## OPERATING STATUS

1. Unit Name: Arkansas Nuclear One - Unit 1
2. Reporting Period: July 1 - 31, 1981
3. Licensed Thermal Power (MWt): 2568
4. Nameplate Rating (Gross MWe): 902.74
5. Design Electrical Rating (Net MWe): 850
6. Maximum Dependable Capacity (Gross MWe): 883
7. Maximum Dependable Capacity (Net MWe): 836
8. If Changes Occur in Capacity Ratings (Items Number 3 Through 7) Since Last Report, Give Reasons:  
NONE

Notes

9. Power Level To Which Restricted, If Any (Net MWe): None
10. Reasons For Restrictions, If Any: N/A

	This Month	Yr.-to-Date	Cumulative
11. Hours In Reporting Period	744.0	5087.0	58002.0
12. Number Of Hours Reactor Was Critical	439.4	3007.6	38797.9
13. Reactor Reserve Shutdown Hours	0.0	149.0	5044.0
14. Hours Generator On-Line	424.1	2913.3	37958.3
15. Unit Reserve Shutdown Hours	0.0	0.0	817.5
16. Gross Thermal Energy Generated (MWH)	1030869.0	7115822.0	91287788.0
17. Gross Electrical Energy Generated (MWH)	336769.0	2370875.0	30069436.0
18. Net Electrical Energy Generated (MWH)	320785.0	2263743.0	28679382.0
19. Unit Service Factor	57.0	57.3	65.4
20. Unit Availability Factor	57.0	57.3	66.9
21. Unit Capacity Factor (Using MDC Net)	51.6	53.2	59.1
22. Unit Capacity Factor (Using DER Net)	50.7	52.4	58.2
23. Unit Forced Outage Rate	43.0	11.4	16.9
24. Shutdowns Scheduled Over Next 6 Months (Type, Date, and Duration of Each):			

25. If Shut Down At End Of Report Period, Estimated Date of Startup: \_\_\_\_\_
26. Units in Test Status (Prior to Commercial Operation):

INITIAL CRITICALITY  
 INITIAL ELECTRICITY  
 COMMERCIAL OPERATION

Forecast	Achieved
_____	_____
_____	_____
_____	_____

REFUELING INFORMATION

DATE: July, 1981

1. Name of facility. Arkansas Nuclear One - Unit 1
2. Scheduled date for next refueling shutdown. 1/1/83
3. Scheduled date for restart following refueling. 3/15/83
4. Will refueling or resumption of operation thereafter require a technical specification change or other license amendment?  
If answer is yes, what, in general, will these be?  
If answer is no, has the reload fuel design and core configuration been reviewed by your Plant Safety Review Committee to determine whether any unreviewed safety questions are associated with the core reload (Ref. 10 CFR Section 50.59)?  
  
Yes. Reload report and associated proposed Technical Specification changes. Also, the safety analysis of eight demonstration high burn-up assemblies will be provided.
5. Scheduled date(s) for submitting proposed licensing action and supporting information. 10/1/82
6. Important licensing considerations associated with refueling, e.g., new or different fuel design or supplier, unreviewed design or performance analysis methods, significant changes in fuel design, new operating procedures.  
  
Will reload 72 fresh fuel assemblies and operate for approximately 16 months. Eight of which will be high burn-up test assemblies.
7. The number of fuel assemblies (a) in the core and (b) in the spent fuel storage pool. a) 177 b) 244
8. The present licensed spent fuel pool storage capacity and the size of any increase in licensed storage capacity that has been requested or is planned, in number of fuel assemblies.  
present 589 increase size by 0
9. The projected date of the last refueling that can be discharged to the spent fuel pool assuming the present licensed capacity.

DATE: 1986

## NRC MONTHLY OPERATING REPORT

### OPERATING SUMMARY - JULY 1981

#### UNIT I

Unit One began the month at 96.7% full power - in a power limited condition due to the downcomer water level of the "A" OTSG. A gradual reduction in the "A" OTSG downcomer water level allowed power to be increased to 99.24% on July 7, 1981. On July 8, 1981, Unit One reactor tripped on high RCS pressure when the "A" MFW pump tripped on low suction pressure. The unit resumed 100% full power operations on July 9, 1981, and continued there until July 15, 1981. On July 15 Unit One was brought to cold shutdown to repair a leaking manway on the primary side of the "A" OTSG. Heatup of Unit One began on July 27, 1981, after repair of the "A" OTSG and 100% full power was attained July 29, 1981. Unit One continued to operate at 100% full power through the end of the month.

## UNIT SHUTDOWNS AND POWER REDUCTIONS

REPORT MONTH July

DOCKET NO. 50-313  
 UNIT NAME ANO - Unit 1  
 DATE August 3, 1981  
 COMPLETED BY J. Gertsch  
 TELEPHONE (501) 968-2519

No.	Date	Type <sup>1</sup>	Duration (Hours)	Reason <sup>2</sup>	Method of Shutting Down Reactor <sup>3</sup>	Licensee Event Report #	System Code <sup>4</sup>	Component Code <sup>5</sup>	Cause & Corrective Action to Prevent Recurrence
81-08	810708	F	6.3	H	3	N/A	CH	PUMPXX	Rx tripped on high RCS pressure when "A" MFW pump tripped on low suction pressure. Cause unknown. Three condensate pumps on line vice two.
81-09	810715	F	298.3	A	1	N/A	CC	HTEXCH	Rx to cold shutdown for repair of leaking manway on primary side of "A" OTSG. Repaired manway.

<sup>1</sup>  
 F: Forced  
 S: Scheduled

<sup>2</sup>  
 Reason:  
 A-Equipment Failure (Explain)  
 B-Maintenance or Test  
 C-Refueling  
 D-Regulatory Restriction  
 E-Operator Training & License Examination  
 F-Administrative  
 G-Operational Error (Explain)  
 H-Other (Explain)

<sup>3</sup>  
 Method:  
 1-Manual  
 2-Manual Scram.  
 3-Automatic Scram.  
 4-Continuation  
 5-Load Reduction  
 9-Other

<sup>4</sup>  
 Exhibit G - Instructions  
 for Preparation of Data  
 Entry Sheets for Licensee  
 Event Report (LER) File (NUREG-  
 0161)

<sup>5</sup>  
 Exhibit I - Same Source

## UNIT SHUTDOWNS AND POWER REDUCTIONS

### INSTRUCTIONS

This report should describe all plant shutdowns during the report period. In addition, it should be the source of explanation of significant dips in average power levels. Each significant reduction in power level (greater than 20% reduction in average daily power level for the preceding 24 hours) should be noted, even though the unit may not have been shut down completely<sup>1</sup>. For such reductions in power level, the duration should be listed as zero, the method of reduction should be listed as 4 (Other), and the Cause and Corrective Action to Prevent Recurrence column should explain. The Cause and Corrective Action to Prevent Recurrence column should be used to provide any needed explanation to fully describe the circumstances of the outage or power reduction.

**NUMBER.** This column should indicate the sequential number assigned to each shutdown or significant reduction in power for that calendar year. When a shutdown or significant power reduction begins in one report period and ends in another, an entry should be made for both report periods to be sure all shutdowns or significant power reductions are reported. Until a unit has achieved its first power generation, no number should be assigned to each entry.

**DATE.** This column should indicate the date of the start of each shutdown or significant power reduction. Report as year, month, and day. August 14, 1977 would be reported as 770814. When a shutdown or significant power reduction begins in one report period and ends in another, an entry should be made for both report periods to be sure all shutdowns or significant power reductions are reported.

**TYPE.** Use "F" or "S" to indicate either "Forced" or "Scheduled," respectively, for each shutdown or significant power reduction. Forced shutdowns include those required to be initiated by no later than the weekend following discovery of an off-normal condition. It is recognized that some judgment is required in categorizing shutdowns in this way. In general, a forced shutdown is one that would not have been completed in the absence of the condition for which corrective action was taken.

**DURATION.** Self-explanatory. When a shutdown extends beyond the end of a report period, count only the time to the end of the report period and pick up the ensuing down time in the following report periods. Report duration of outages rounded to the nearest tenth of an hour to facilitate summation. The sum of the total outage hours plus the hours the generator was on line should equal the gross hours in the reporting period.

**REASON.** Categorize by letter designation in accordance with the table appearing on the report form. If category H must be used, supply brief comments.

**METHOD OF SHUTTING DOWN THE REACTOR OR REDUCING POWER.** Categorize by number designation

<sup>1</sup>Note that this differs from the Edison Electric Institute (EEI) definitions of "Forced Partial Outage" and "Scheduled Partial Outage." For these terms, EEI uses a change of 30 MW as the break point. For larger power reactors, 30 MW is too small a change to warrant explanation.

in accordance with the table appearing on the report form. If category 4 must be used, supply brief comments.

**LICENSEE EVENT REPORT #.** Reference the applicable reportable occurrence pertaining to the outage or power reduction. Enter the first four parts (event year, sequential report number, occurrence code and report type) of the five part designation as described in Item 17 of Instructions for Preparation of Data Entry Sheets for Licensee Event Report (LER) File (NUREG-0161). This information may not be immediately evident for all such shutdowns, of course, since further investigation may be required to ascertain whether or not a reportable occurrence was involved.) If the outage or power reduction will not result in a reportable occurrence, the positive indication of this lack of correlation should be noted as not applicable (N/A).

**SYSTEM CODE.** The system in which the outage or power reduction originated should be noted by the two digit code of Exhibit G - Instructions for Preparation of Data Entry Sheets for Licensee Event Report (LER) File (NUREG-0161).

Systems that do not fit any existing code should be designated XX. The code ZZ should be used for those events where a system is not applicable.

**COMPONENT CODE.** Select the most appropriate component from Exhibit I - Instructions for Preparation of Data Entry Sheets for Licensee Event Report (LER) File (NUREG-0161), using the following criteria:

- If a component failed, use the component directly involved.
- If not a component failure, use the related component e.g., wrong valve operated through error; list valve as component.
- If a chain of failures occurs, the first component to malfunction should be listed. The sequence of events, including the other components which fail, should be described under the Cause and Corrective Action to Prevent Recurrence column.

Components that do not fit any existing code should be designated XXXXXX. The code ZZZZZZ should be used for events where a component designation is not applicable.

**CAUSE & CORRECTIVE ACTION TO PREVENT RECURRENCE.** Use the column in a narrative fashion to amplify or explain the circumstances of the shutdown or power reduction. The column should include the specific cause for each shutdown or significant power reduction and the immediate and contemplated long term corrective action taken, if appropriate. This column should also be used for a description of the major safety-related corrective maintenance performed during the outage or power reduction including an identification of the critical path activity and a report of any single release of radioactivity or single radiation exposure specifically associated with the outage which accounts for more than 10 percent of the allowable annual values.

For long textual reports continue narrative on separate paper and reference the shutdown or power reduction for this narrative.