

50.55(e) Report

RECEIVED
NRC

ARIZONA



PUBLIC SERVICE COMPANY

STA. 3003

P.O. BOX 21666 - PHOENIX, ARIZONA 85036

October 28, 1982

ANPP-22139-GHD/BSK

U. S. Nuclear Regulatory Commission
Region V
Creskide Oaks Office Park
1450 Maria Lane - Suite 210
Walnut Creek, California 94596-5368

Attention: Mr. D. M. Sternberg, Chief
Reactor Projects Branch 1

Subject: Time Extension for Report - DER 82-37
A 50.55(e) Potentially Reportable Deficiency Relating to
Class 1E Wiring Terminations Crimped With Less Pressure
Than Specified, Due to Lack of Maintenance Program and
Traceability For AMP Hydraulic Crimp Tools
File: 82-019-026
D.4.33.2

Reference: (A) Telephone Conversation between T. Bishop and G. Duckworth
on July 13, 1982
(B) ANPP-21591 dated August 10, 1982 (Interim Report)

Dear Sir:

The NRC was notified of a potentially reportable deficiency in Reference (A),
and an Interim Report was transmitted by Reference (B). At that time, it
was estimated that a Final Report would be available by October 21, 1982.

Due to the extensive investigation and evaluation required, it is now
expected that this information will be finalized by November 18, 1982,
when a complete report will be submitted.

There is no new information or change to the Interim Report at this time.

Very truly yours,

E. E. Van Brunt, Jr.
APS Vice President
Nuclear Projects Management
ANPP Project Director

EEVBJr/GHD:db

cc: See Attached Page 2

8211150669 821028
PDR ADOCK 05000528
S PDR

IE27

U. S. Nuclear Regulatory Commission
Attention: Mr. D. M. Sternberg, Chief
Page 2

October 28, 1982
ANPP-22139-GHD/BSK

cc: Richard DeYoung, Director
Office of Inspection and Enforcement
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

T. G. Woods, Jr.
J. A. Roedel
D. B. Fasnacht
G. C. Andognini
A. C. Rogers
B. S. Kaplan
W. E. Ide
J. Vorees
J. A. Brand
A. C. Gehr
W. J. Stubblefield
W. G. Bingham
R. L. Patterson
R. W. Welcher
R. M. Grant
D. R. Hawkinson
L. E. Vorderbrueggen
G. A. Fiorelli

Lynne Bernabei, Esq.
Harmon & Weiss
1725 "I" Street, NW
Suite 506
Washington, D. C. 20006

R. L. Greenfield
Assistant Attorney General
Bataan Memorial Building
Santa Fe, New Mexico 87503