



Pennsylvania Power & Light Company

Two North Ninth Street • Allentown, PA 18101 • 215 / 770-5151

November 3, 1982

Mr. R.C. Haynes
Director, Region I
U.S. Nuclear Regulatory Commission
631 Park Avenue
King of Prussia, PA 19406

SUSQUEHANNA STEAM ELECTRIC STATION
LICENSEE EVENT REPORT 82-034/03L-0
ER 100450 FILE 841-23
PLA- 137

Docket No. 50-387
License No. NPF-14

Dear Mr. Haynes:

Attached please find a copy of Licensee Event Report No. 82-034/03L-0. This event was determined to be reportable per Technical Specification 6.9.1.9.b, in that the Control Room Emergency Outside Air Supply System "A" train was declared inoperable after an inlet damper failed to close.

H.W. Keiser
Superintendent of Plant-Susquehanna

DGM/cw

cc: A. Schwencer
Division of Licensing
U.S. Nuclear Regulatory Commission
Washington, DC 20555

G. Rhoads
Resident Inspector
U.S. Nuclear Regulatory Commission
P.O. Box 52
Shickshinny, Pa. 18655

8211180351 821103
PDR ADOCK 05000387
S PDR

Ter