

**LICENSEE EVENT REPORT**

LER 82-22/3L

CONTROL BLOCK:

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0	1	V	T	V	Y	S	1	2	0	0	-	0	0	0	0	-	0	0	3	4	1	1	1	1	4			5	
7	9	LICENSEE CODE						14	LICENSE NUMBER												25	LICENSE TYPE					30	57 CAT 58	

CON'T

REPORT SOURCE L 6 0 5 0 0 0 2 7 1 7 1 0 0 5 8 2 8 1 1 0 3 8 2 9

60 61 DOCKET NUMBER 68 69 EVENT DATE 74 75 REPORT DATE 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 While performing monthly Emergency Diesel Generator surveillance, the "A" Diesel  
0 3 Generator failed to reach its required voltage and frequency in the time required  
0 4 by Tech. Spec. Section 3.10.A.1. There were no consequences to the public health  
0 5 and safety as a result of this event. No similar occurrences of this type have been  
0 6 reported to the Commission.  
0 7  
0 8

SYSTEM CODE E E (11)		CAUSE CODE E (12)		CAUSE SUBCODE B (13)		COMPONENT CODE V A L V E X (14)		COMP. SUBCODE C (15)		VALVE SUBCODE A (16)	
LER-RO REPORT NUMBER 8 9 (17)		EVENT YEAR 8 2 (21)		SEQUENTIAL REPORT NO. 0 2 2 (24)		OCCURRENCE CODE 0 3 (28)		REPORT TYPE L (30)		REVISION NO. 0 (32)	
ACTION TAKEN C (18)		FUTURE ACTION Z (19)		EFFECT ON PLANT Z (20)		SHUTDOWN METHOD Z (21)		HOURS 0 0 0 0 (22)		ATTACHMENT SUBMITTED N (23)	
NPRD-4 FORM SUB. Y (24)		PRIME COMP. SUPPLIER A (25)		COMPONENT MANUFACTURER T 0 8 3 (26)							

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 The cause of this event was attributed to the failure of a check valve on the fuel  
1 1 oil return line from the diesel cylinders to the fuel oil day tank. This caused  
1 2 the fuel oil in the cylinder supply line to drain, resulting in the motor driven  
1 3 pump requiring additional time to make this up. The valve was replaced and the  
1 4 diesel satisfactorily tested.

1 5 E (28) 1 0 0 (29) NA (30) METHOD OF DISCOVERY (31) B (31) Surveillance Test (32) DISCOVERY DESCRIPTION (32)  
 7 8 9 10 11 12 13 44 45 46 80  
 ACTIVITY CONTENT RELEASED OF RELEASE AMOUNT OF ACTIVITY (35) LOCATION OF RELEASE (36)  
 1 6 Z (33) 1 0 (34) NA (36)  
 7 8 9 10 11 12 13 44 45 46 80

PERSONNEL EXPOSURES

NUMBER		TYPE	DESCRIPTION
1	7	000	NA

PERSONNEL INJURIES		NUMBER		DESCRIPTION	
1	8	0	0	40	NA

1	9	42	LOSS OF OR DAMAGE TO FACILITY TYPE DESCRIPTION	43	NA
---	---	----	--	----	----

ISSUED (2) (0) (N) (44) PUBLICITY DESCRIPTION (45) NA NRC USE ONLY

NRC USE ONLY

8211180480 821103  
PDR ADDCK 05000271  
S PDR

James P. Pelletier

PHONE: (802) 257-7711

0  
0  
0  
0  
0