

LICENSEE EVENT REPORT

CONTROL BLOCK: 1

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 | G | A | E | I | H | 2 | 2 | 0 | 0 | - | 0 | 0 | 0 | 0 | - | 0 | 0 | 3 | 4 | 1 | 1 | 1 | 1 | 4 | 5

7 8 9 14 15 25 26 30 57 CAT 58

CON'T

01 | L | 6 | 0 | 5 | 0 | 0 | 0 | 3 | 6 | 6 | 7 | 1 | 0 | 2 | 8 | 8 | 2 | 8 | 1 | 1 | 1 | 1 | 8 | 2 | 9

7 8 60 61 68 69 74 75 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 | During the performance of the "MAIN STEAM LINE ISOLATION VALVE TRIP TEST"

03 | procedure, the "B" outboard main steam isolation valve failed to meet the

04 | "greater than 3 less than 5 seconds" closure time of Tech. Specs. Table

05 | 3.6.3-1, item A.1; closure time was 1.6 seconds. A 4-hour LCO was

06 | declared per Tech. Specs. 3.6.3, ACTION a. The valve was deactivated in

07 | the closed position and the LCO cleared per Action a.2. The health and

08 | safety of the public were not affected by this non-repetitive event.

7 8 9 80

09 | S | F | 11 | E | 12 | B | 13 | V | A | L | V | O | P | 14 | B | 15 | Z | 16

7 8 9 10 11 12 13 18 19 20

17 | LER/RO REPORT NUMBER | 8 | 2 | 21 | 22 | 1 | 2 | 1 | 24 | 26 | 0 | 3 | 28 | 29 | L | 30 | 31 | 0 | 32

18 | 8 | 2 | 21 | 22 | 1 | 2 | 1 | 24 | 26 | 0 | 3 | 28 | 29 | L | 30 | 31 | 0 | 32

19 | A | 18 | Z | 19 | Z | 20 | Z | 21 | 0 | 0 | 0 | 0 | 22 | N | 23 | N | 24 | N | 25 | L | 2 | 0 | 0 | 26

33 34 35 36 37 40 41 42 43 44 47

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 | The cause of the "B" outboard valve failing to meet closing time require

11 | ments was due to a blown shaft seal and a faulty speed controller. The

12 | seal and the speed controller were replaced. The valve successfully met

13 | all requirements of the "MAIN STEAM LINE ISOLATION VALVE TRIP TEST"

14 | procedure on 10/30/82 and was returned to service.

7 8 9 80

15 | E | 28 | 0 | 5 | 9 | 29 | NA | 30 | B | 31 | Performance Test | 32

7 8 9 10 12 13 44 45 46 80

16 | Z | 33 | Z | 34 | NA | 35 | NA | 36

7 8 9 10 11 44 45 80

17 | 0 | 0 | 0 | 37 | Z | 38 | NA | 39

7 8 9 11 12 13 80

18 | 0 | 0 | 0 | 40 | NA | 41

7 8 9 11 12 80

19 | Z | 42 | NA | 43

7 8 9 10 80

20 | N | 44 | NA | 45

7 8 9 10 80

NAME OF PREPARER S. B. Tipps

8211220234 821111
PDR ADOCK 05000366
S PDR

NRC USE ONLY

PHONE: (912) 367-7851