

Arizona Public Service Company

P.O. BOX 21666 • PHOENIX, ARIZONA 85036

November 4, 1982

ANPP-22204-GHD/BSK

U. S. Nuclear Regulatory Commission
Region V
Creskide Oaks Office Park
1450 Maria Lane - Suite 210
Walnut Creek, California 94596-5368

Attention: Mr. D. M. Sternberg, Chief
Reactor Projects Branch 1

Subject: Time Extension for Report - DER 82-42
A 50.55(e) Potentially Reportable Deficiency Relating to
Unit 1 Reactor Coolant Pump Pressure Tap Nozzle Weld
Leak Due to Overheating Stainless Alloy
File: 82-019-026
D.4.33.2

Reference: (A) Telephone Conversation Between J. Eckhardt and
G. Duckworth on July 9, 1982
(B) ANPP-21577 dated August 9, 1982 (Interim Report)

Dear Sir:

The NRC was notified of a potentially reportable deficiency in
Reference (A) and an Interim Report was transmitted by Reference (B).
At that time, it was estimated that a Final Report would be available by
November 4, 1982.

Due to the extensive investigation and evaluation required, it is now
expected that this information will be finalized by December 29, 1982,
when a complete report will be submitted.

There is no change to the Interim Report at this time.

Very truly yours,

E. E. Van Brunt

E. E. Van Brunt, Jr.
APS Vice President
Nuclear Projects Management
ANPP Project Director

EEVBJr/GHD:db

cc: See Attached Page 2

NOV 12 PM 1:30

RECEIVED
MNC

1E27

U. S. Nuclear Regulatory Commission
Attention: Mr. D. M. Sternberg, Chief

November 4, 1982
ANPP-22204-GHD/BSK

cc: Richard DeYoung, Director
Office of Inspection and Enforcement
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

T. G. Woods, Jr.
J. A. Roedel
D. B. Fasnacht
G. C. Andognini
A. C. Rogers
B. S. Kaplan
W. E. Ide
J. Vorees
J. A. Brand
A. C. Gehr
W. J. Stubblefield
W. G. Bingham
R. L. Patterson
R. W. Welcher
R. M. Grant
D. R. Hawkinson
L. E. Vorderbrueggen
G. A. Fiorelli

Lynne Bernabei, Esq.
Harmon & Weiss
1725 "I" Street, NW
Suite 506
Washington, D. C. 20006

R. L. Greenfield
Assistant Attorney General
Bataan Memorial Building
Santa Fe, New Mexico 87503