

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0	1	N		C	B	E	P	2	2	0	0	-	0	0	0	0	0	-	0	0	3	4	1	1	1	1	4		5
7	8	9		13				14	15	25										26	30				57	58			
RESERVED		LICENSEE CODE						LICENSE NUMBER										LICENSE TYPE				CAT							

REPORT SOURCE DOCKET NUMBER EVENT DATE REPORT DATE

0	1	L	6	0	5	0	-	0	3	2	4	7	1	0	0	9	8	2	8	1	1	0	5	8	2	9
7	8	60	61									68	69					74	75							80

0 2 | During plant operation, while performing a whole-core LPRM calibration and base
0 3 | distribution using the TIP System, the isolating function of "A" TIP guide tube
0 4 | primary containment isolation ball valve became inoperable when an electrical trip of
0 5 | the TIP machine occurred as the machine probe was being fully inserted into the core.
0 6 | At the time of this event, the "A" TIP manual isolation shear valve was operable.
0 7 | This event did not affect the health and safety of the public.

09		SYSTEM CODE		CAUSE CODE		CAUSE SUBCODE		COMPONENT CODE				COMP. SUBCODE		VALVE SUBCODE			
0	9	S	D	E	X	V	A	L	V	E	X	A	D				
7	8	9	10	11	12	13	14	15	16	17	18	19	20				
(17) LER/RO REPORT NUMBER		EVENT YEAR		SEQUENTIAL REPORT NO.		OCCURRENCE CODE		REPORT TYPE		REVISION NO.							
82		82		121		03		L		0							
21		22		24		28		30		32							
ACTION TAKEN		FUTURE ACTION		EFFECT ON PLANT		SHUTDOWN METHOD		HOURS		ATTACHMENT SUBMITTED		NPRD-4 FORM SUB.		PRIME COMP. SUPPLIER		COMPONENT MANUFACTURER	
X		X		Z		Z		0000		N		N		N		G080	
33		34		35		36		37		41		42		43		44	
(18)		(19)		(20)		(21)		(22)		(23)		(24)		(25)		(26)	

1 0 The "A" TIP probe was manually retracted and the "A" TIP guide tube ball valve

1 1 operability was reestablished within two hours and ten minutes. A preliminary inves-

1 2 tigation has determined a problem with the TIP drive tubing contributed to this event.

1 3 Following a complete determination of the event cause and performed corrective actions

1 4 to it, a supplement to this report will be submitted.

FACILITY STATUS		% POWER		OTHER STATUS		METHOD OF DISCOVERY		DISCOVERY DESCRIPTION	
1	5	E	28	0	5	7	29	NA	30
ACTIVITY CONTENT		RELEASED OF RELEASE		AMOUNT OF ACTIVITY		LOCATION OF RELEASE			
1	6	Z	33	Z	34	NA	35	NA	36
PERSONNEL EXPOSURES		NUMBER		TYPE		DESCRIPTION			
1	7	0	0	0	37	Z	38	NA	39
PERSONNEL INJURIES		NUMBER		DESCRIPTION					
1	8	0	0	0	40	NA	41	NA	42
LOSS OF OR DAMAGE TO FACILITY		TYPE		DESCRIPTION					
1	9	Z	42	NA	43	NA	44	NA	45

7 8 9 10 80

PUBLICITY

ISSUED DESCRIPTION (45) NRC USE ONLY

2 0 N 44 S PDR

3 8 9 10 68 69 80

NAME OF PREPARER M. J. Pastva, Jr.

NRC USE ONLY

68 69

919-457-9521

PHONE: