



September 26, 1990

Donald F. Schnell
Senior Vice President
Nuclear

U.S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Mail Station P1-137
Washington, D.C. 20555

Gentlemen:

ULRNC-2295


DOCKET NUMBER 50-483
CALLAWAY PLANT
STEAM GENERATOR ATMOSPHERIC STEAM DUMP VALVES

Union Electric Company herewith transmits an application for amendment to Facility Operating License No. NPF-30 for the Callaway Plant. This amendment application requests a revision to Technical Specification 3/4 7.1.7 to allow an exception to Technical Specification 4.0.4. This amendment is required because the surveillances for the steam generator atmospheric steam dump valves can only be completed after entry into a mode for which the surveillance requirements apply.

The Callaway Plant On-Site Review Committee and the Nuclear Safety Review Board have reviewed and approved this amendment application. Attachments 1 through 3 provide the Technical Specification changes, Safety Evaluation, and Significant Hazards Evaluation, respectively. It has been determined that this amendment application does not involve any unreviewed safety questions, as defined in 10CFR50.59, nor a significant hazard consideration as determined per 10CFR50.92.

Approval of this amendment application is required prior to entry into Mode 3 at the conclusion of the current refueling outage. Mode 3 is scheduled to be entered on November 4. Your expeditious handling of the request is appreciated. If you have any questions on this amendment application, please contact us.

Very truly yours,


for Donald F. Schnell

DS/plh

Attachments: 1. Technical Specification Changes
2. Safety Evaluation
3. Significant Hazards Evaluation

00101

A001
111

STATE OF MISSOURI)
) S S
CITY OF ST. LOUIS)

Alan C. Passwater, of lawful age, being first duly sworn upon oath says that he is Manager, Licensing and Fuels (Nuclear) for Union Electric Company; that he has read the foregoing document and knows the content thereof; that he has executed the same for and on behalf of said company with full power and authority to do so; and that the facts therein stated are true and correct to the best of his knowledge, information and belief.

By Alan C. Passwater
Alan C. Passwater
Manager, Licensing and Fuels
Nuclear

SUBSCRIBED and sworn to before me this 26th day
of September, 1990.

Barbara J. Pfaff
BARBARA J. PFAFF
NOTARY PUBLIC, STATE OF MISSOURI
MY COMMISSION EXPIRES APRIL 22, 1993
ST. LOUIS COUNTY

cc: T. A. Baxter, Esq.
Shaw, Pittman, Potts & Trowbridge
2300 N. Street, N.W.
Washington, D.C. 20037

Dr. J. O. Cermak
CFA, Inc.
4 Professional Drive (Suite 110)
Gaithersburg, MD 20879

R. C. Knop
Chief, Reactor Project Branch 1
U.S. Nuclear Regulatory Commission
Region III
799 Roosevelt Road
Glen Ellyn, Illinois 60137

Bruce Bartlett
Callaway Resident Office
U.S. Nuclear Regulatory Commission
RR#1
Steedman, Missouri 65077

Anthony T. Gody, Jr. (2)
Office of Nuclear Reactor Regulation
U.S. Nuclear Regulatory Commission
1 White Flint, North, Mail Stop 13E21
11555 Rockville Pike
Rockville, MD 20852

Manager, Electric Department
Missouri Public Service Commission
P.O. Box 360
Jefferson City, MO 65102

Ron Kucera
Department of Natural Resources
P.O. Box 176
Jefferson City, MO 65102