



Tennessee Valley Authority, 1101 Market Street, Chattanooga, Tennessee 37402

FEB 19 1991

U.S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, D.C. 20555

Gentlemen:

| | | |
|----------------------------|---|--------------------|
| In the Matter of |) | Docket Nos. 50-327 |
| Tennessee Valley Authority |) | 50-328 |

SEQUOYAH NUCLEAR PLANT (SQN) - PARTIAL LIST OF CYCLE 4 REFUELING OUTAGE ACCOMPLISHMENTS

As requested by the Sequoyah NRC Project Manager, enclosed is a partial list of Cycle 4 refueling outage accomplishments relevant to issues tracked by NRC (i.e., Generic Letter 89-06 and various technical specification changes). In addition, a more comprehensive update will follow in response to NRC's request to update the safety issue's management system data base.

Please direct questions concerning this issue to J. D. Smith at (615) 843-6672.

Very truly yours,

TENNESSEE VALLEY AUTHORITY

E. G. Wallace, Manager
Nuclear Licensing and
Regulatory Affairs

Enclosure
cc: See page 2

9102210322 910219
PDR ADOCK 05000327
PDR

200000

A001
1/1

U.S. Nuclear Regulatory Commission

FEB 19 1991

cc (Enclosure):

Ms. S. C. Black, Deputy Director
Project Directorate II-4
U.S. Nuclear Regulatory Commission
One White Flint, North
11555 Rockville Pike
Rockville, Maryland 20852

Mr. J. N. Donohew, Project Manager
U.S. Nuclear Regulatory Commission
One White Flint, North
11555 Rockville Pike
Rockville, Maryland 20852

NRC Resident Inspector
Sequoyah Nuclear Plant
2600 Igou Ferry Road
Soddy Daisy, Tennessee 37379

Mr. B. A. Wilson, Project Chief
U.S. Nuclear Regulatory Commission
Region II
101 Marietta Street, NW, Suite 2900
Atlanta, Georgia 30323

ENCLOSURE

| <u>ISSUE</u> | <u>TAC NO. (U1/U2)</u> | <u>UNIT 1 IMPLEMENTATION DATES</u> | <u>UNIT 2 IMPLEMENTATION DATES</u> |
|--|------------------------|--|--|
| 1. TS 89-06 Safety Parameter Display System | M73707/M73708 | 6/90 | 12/90 |
| 2. TS 89-18 Delete RHR System Auto Closure Interlock | M75523/M75524 | 5/90 | 10/90 |
| 3. TS 89-25 Removal of the Upper Head Injection System | M75747/M75748 | 5/90 | 11/90 |
| 4. TS 89-26 Delete the Boron Injection Tank Function | M75749/M75750 | 5/90 | 11/90 |
| 5. TS 90-07 Addition of Two Smoke Detectors in Volume Control Tank Room | M76772/M76773 | 8/90 | 1/91 |
| 6. TS 89-33 Use of Vantage 5 Hybrid (5H) Fuel to Operate Unit | M75751/M75752 | 5/90 | 11/90 |
| 7. TS 90-14 FCV vs FSV Revise Valve Nomenclature For 14 Containment Isolation Valves | M76844/M76845 | 10/90 | 1/91 |