

EMERGENCY PLAN CHANGE SCREENING AND EFFECTIVENESS EVALUATIONS 10 CFR 50.54(Q)	AD-EP-ALL-0602	
	Rev. 6	

ATTACHMENT 4

Page 1 of 4

<< 10 CFR 50.54(q) Screening Evaluation Form >>

Screening and Evaluation Number		Applicable Sites													
EREG #: <u>02304334</u>		BNP	<input type="checkbox"/>												
		CNS	<input type="checkbox"/>												
		CR3	<input type="checkbox"/>												
		HNP	<input type="checkbox"/>												
5AD #: <u>02304275</u>		MNS	<input checked="" type="checkbox"/>												
		ONS	<input type="checkbox"/>												
		RNP	<input type="checkbox"/>												
		GO	<input type="checkbox"/>												
Document and Revision	RP/0/A/5700/003 - SITE AREA EMERGENCY Revision 38														
<p>Part I. Description of Activity Being Reviewed (event or action, or series of actions that may result in a change to the emergency plan or affect the implementation of the emergency plan):</p> <p>MNS Site EP Procedure RP/0/A/5700/003 (SITE AREA EMERGENCY) is being superseded to Fleet EP Procedure AD-EP-ALL-0111 (CONTROL ROOM ACTIVATION OF THE ERO) as part of the Common Control Room Procedures Fleet EP project.</p>															
<table border="1"> <thead> <tr> <th>Part II. Activity Previously Reviewed?</th> <th>Yes</th> <th><input type="checkbox"/></th> <th>No</th> <th><input checked="" type="checkbox"/></th> </tr> </thead> <tbody> <tr> <td> <p>Is this activity Fully bounded by an NRC approved 10 CFR 50.90 submittal or Alert and Notification System Design Report?</p> <p>If yes, identify bounding source document number or approval reference and ensure the basis for concluding the source document fully bounds the proposed change is documented below:</p> <p>Justification:</p> </td> <td colspan="2"> <p>10 CFR 50.54(q) Effectiveness Evaluation is not required. Enter justification below and complete Attachment 4, Part V.</p> </td> <td colspan="2"> <p>Continue to Attachment 4, 10 CFR 50.54(q) Screening Evaluation Form, Part III</p> </td> </tr> </tbody> </table>						Part II. Activity Previously Reviewed?	Yes	<input type="checkbox"/>	No	<input checked="" type="checkbox"/>	<p>Is this activity Fully bounded by an NRC approved 10 CFR 50.90 submittal or Alert and Notification System Design Report?</p> <p>If yes, identify bounding source document number or approval reference and ensure the basis for concluding the source document fully bounds the proposed change is documented below:</p> <p>Justification:</p>	<p>10 CFR 50.54(q) Effectiveness Evaluation is not required. Enter justification below and complete Attachment 4, Part V.</p>		<p>Continue to Attachment 4, 10 CFR 50.54(q) Screening Evaluation Form, Part III</p>	
Part II. Activity Previously Reviewed?	Yes	<input type="checkbox"/>	No	<input checked="" type="checkbox"/>											
<p>Is this activity Fully bounded by an NRC approved 10 CFR 50.90 submittal or Alert and Notification System Design Report?</p> <p>If yes, identify bounding source document number or approval reference and ensure the basis for concluding the source document fully bounds the proposed change is documented below:</p> <p>Justification:</p>	<p>10 CFR 50.54(q) Effectiveness Evaluation is not required. Enter justification below and complete Attachment 4, Part V.</p>		<p>Continue to Attachment 4, 10 CFR 50.54(q) Screening Evaluation Form, Part III</p>												
Bounding document attached (optional)					<input type="checkbox"/>										
<table border="1"> <thead> <tr> <th>Part III. Editorial Change</th> <th>Yes</th> <th><input type="checkbox"/></th> <th>No or Partially</th> <th><input checked="" type="checkbox"/></th> </tr> </thead> <tbody> <tr> <td> <p>Is this activity an editorial or typographical change only, such as formatting, paragraph numbering, spelling, or punctuation that does not change intent?</p> <p>Justification:</p> </td> <td colspan="2"> <p>10 CFR 50.54(q) Effectiveness Evaluation is not required. Enter justification and complete Attachment 4, Part V.</p> </td> <td colspan="2"> <p>Continue to Attachment 4, Part IV and address non editorial changes</p> </td> </tr> </tbody> </table>						Part III. Editorial Change	Yes	<input type="checkbox"/>	No or Partially	<input checked="" type="checkbox"/>	<p>Is this activity an editorial or typographical change only, such as formatting, paragraph numbering, spelling, or punctuation that does not change intent?</p> <p>Justification:</p>	<p>10 CFR 50.54(q) Effectiveness Evaluation is not required. Enter justification and complete Attachment 4, Part V.</p>		<p>Continue to Attachment 4, Part IV and address non editorial changes</p>	
Part III. Editorial Change	Yes	<input type="checkbox"/>	No or Partially	<input checked="" type="checkbox"/>											
<p>Is this activity an editorial or typographical change only, such as formatting, paragraph numbering, spelling, or punctuation that does not change intent?</p> <p>Justification:</p>	<p>10 CFR 50.54(q) Effectiveness Evaluation is not required. Enter justification and complete Attachment 4, Part V.</p>		<p>Continue to Attachment 4, Part IV and address non editorial changes</p>												

EMERGENCY PLAN CHANGE SCREENING AND EFFECTIVENESS EVALUATIONS 10 CFR 50.54(Q)	AD-EP-ALL-0602
	Rev. 6

ATTACHMENT 4

Page 2 of 4

<< 10 CFR 50.54(q) Screening Evaluation Form >>

Part IV. Emergency Planning Element and Function Screen (Reference Attachment 1, Considerations for Addressing Screening Criteria)		
Does this activity involve any of the following, including program elements from NUREG-0654/FEMA REP-1 Section II? If answer is yes, then check box.		
1	10 CFR 50.47(b)(1) Assignment of Responsibility (Organization Control)	
1a	Responsibility for emergency response is assigned.	<input checked="" type="checkbox"/>
1b	The response organization has the staff to respond and to augment staff on a continuing basis (24-7 staffing) in accordance with the emergency plan.	<input type="checkbox"/>
2	10 CFR 50.47(b)(2) Onsite Emergency Organization	
2a	Process ensures that onshift emergency response responsibilities are staffed and assigned	<input checked="" type="checkbox"/>
2b	The process for timely augmentation of onshift staff is established and maintained.	<input checked="" type="checkbox"/>
3	10 CFR 50.47(b)(3) Emergency Response Support and Resources	
3a	Arrangements for requesting and using off site assistance have been made.	<input type="checkbox"/>
3b	State and local staff can be accommodated at the EOF in accordance with the emergency plan. (NA for CR3)	<input type="checkbox"/>
4	10 CFR 50.47(b)(4) Emergency Classification System	
4a	A standard scheme of emergency classification and action levels is in use. (Requires final approval of Screen and Evaluation by EP CFAM.)	<input type="checkbox"/>
5	10 CFR 50.47(b)(5) Notification Methods and Procedures	
5a	Procedures for notification of State and local governmental agencies are capable of alerting them of the declared emergency within 15 minutes (60 minutes for CR3) after declaration of an emergency and providing follow-up notification.	<input checked="" type="checkbox"/>
5b	Administrative and physical means have been established for alerting and providing prompt instructions to the public within the plume exposure pathway. (NA for CR3)	<input type="checkbox"/>
5c	The public ANS meets the design requirements of FEMA-REP-10, Guide for Evaluation of Alert and Notification Systems for Nuclear Power Plants, or complies with the licensee's FEMA-approved ANS design report and supporting FEMA approval letter. (NA for CR3)	<input type="checkbox"/>

EMERGENCY PLAN CHANGE SCREENING AND EFFECTIVENESS EVALUATIONS 10 CFR 50.54(Q)	AD-EP-ALL-0602
	Rev. 6

ATTACHMENT 4
Page 3 of 4

<< 10 CFR 50.54(q) Screening Evaluation Form >>

Part IV. Emergency Planning Element and Function Screen (cont.)		
6	10 CFR 50.47(b)(6) Emergency Communications	
6a	Systems are established for prompt communication among principal emergency response organizations.	<input type="checkbox"/>
6b	Systems are established for prompt communication to emergency response personnel.	<input type="checkbox"/>
7	10 CFR 50.47(b)(7) Public Education and Information	
7a	Emergency preparedness information is made available to the public on a periodic basis within the plume exposure pathway emergency planning zone (EPZ). (NA for CR3)	<input type="checkbox"/>
7b	Coordinated dissemination of public information during emergencies is established.	<input type="checkbox"/>
8	10 CFR 50.47(b)(8) Emergency Facilities and Equipment	
8a	Adequate facilities are maintained to support emergency response.	<input type="checkbox"/>
8b	Adequate equipment is maintained to support emergency response.	<input type="checkbox"/>
9	10 CFR 50.47(b)(9) Accident Assessment	
9a	Methods, systems, and equipment for assessment of radioactive releases are in use.	<input checked="" type="checkbox"/>
10	10 CFR 50.47(b)(10) Protective Response	
10a	A range of public PARs is available for implementation during emergencies. (NA for CR3)	<input type="checkbox"/>
10b	Evacuation time estimates for the population located in the plume exposure pathway EPZ are available to support the formulation of PARs and have been provided to State and local governmental authorities. (NA for CR3)	<input type="checkbox"/>
10c	A range of protective actions is available for plant emergency workers during emergencies, including those for hostile action events.	<input checked="" type="checkbox"/>
10d	KI is available for implementation as a protective action recommendation in those jurisdictions that chose to provide KI to the public.	<input type="checkbox"/>
11	10 CFR 50.47(b)(11) Radiological Exposure Control	
11a	The resources for controlling radiological exposures for emergency workers are established.	<input type="checkbox"/>
12	10 CFR 50.47(b)(12) Medical and Public Health Support	
12a	Arrangements are made for medical services for contaminated, injured individuals.	<input type="checkbox"/>
13	10 CFR 50.47(b)(13) Recovery Planning and Post-accident Operations	
13a	Plans for recovery and reentry are developed.	<input type="checkbox"/>
14	10 CFR 50.47(b)(14) Drills and Exercises	
14a	A drill and exercise program (including radiological, medical, health physics and other program areas) is established.	<input type="checkbox"/>
14b	Drills, exercises, and training evolutions that provide performance opportunities to develop, maintain, and demonstrate key skills are assessed via a formal critique process in order to identify weaknesses.	<input type="checkbox"/>
14c	Identified weaknesses are corrected.	<input type="checkbox"/>
15	10 CFR 50.47(b)(15) Emergency Response Training	
15a	Training is provided to emergency responders.	<input type="checkbox"/>

EMERGENCY PLAN CHANGE SCREENING AND EFFECTIVENESS EVALUATIONS 10 CFR 50.54(Q)	AD-EP-ALL-0602
	Rev. 6

ATTACHMENT 4

Page 4 of 4

<< 10 CFR 50.54(q) Screening Evaluation Form >>

Part IV. Emergency Planning Element and Function Screen (cont.)		
16	10 CFR 50.47(b)(16) Emergency Plan Maintenance	
16a	Responsibility for emergency plan development and review is established.	<input type="checkbox"/>
16b	Planners responsible for emergency plan development and maintenance are properly trained.	<input type="checkbox"/>
PART IV. Conclusion		
If no Part IV criteria are checked, then provide Justification and complete Part V below. Justification: Change to be evaluated.		<input type="checkbox"/>
If any Attachment 4, 10 CFR 50.54(q) Screening Evaluation Form, Part IV criteria are checked, then complete Attachment 4, 10 CFR 50.54(q) Screening Evaluation Form, Part V and perform a 10 CFR 50.54(q) Effectiveness Evaluation. Program Element 4a requires final approval of Screen and Evaluation by EP CFAM.		<input checked="" type="checkbox"/>
Part V. Signatures:		
EP CFAM Final Approval is required for changes affecting Program Element 4a. If CFAM approval is NOT required, then mark the EP CFAM signature block as not applicable (N/A) to indicate that signature is not required.		
Preparer Name (Print): Barry Kimray	Preparer Signature: See CAS	Date: See CAS
Reviewer Name (Print): See CAS	Reviewer Signature: See CAS	Date: See CAS
Approver (Manager, Nuclear Support Services) Name (Print): See CAS	Approver Signature: See CAS	Date: See CAS
Approver (EP CFAM, as required) Name (Print) N/A	Approver Signature: N/A	Date: N/A
If the proposed activity is a change to the E-Plan, then initiate PRRs. If the proposed activity is a change to the E-Plan, then create two EREG General assignments		
If required by Section 5.6, Submitting Reports of Changes to the NRC, then create two EREG General Assignments.		<input type="checkbox"/>
<ul style="list-style-type: none"> One for EP to provide the 10 CFR 50.54(q) summary of the analysis, or the completed 10 CFR 50.54(q), to Licensing. One for Licensing to submit the 10 CFR 50.54(q) information to the NRC within 30 days after the change is put in effect. 		<input checked="" type="checkbox"/>

QA RECORD