

DISCHARGE MONITORING REPORT (DMR)

Form Approved
DMS No. 158-R0021GP AT
17 2

DELAWARE RIVER

NOTE: Read instructions before completing this form.

PARAMETER (12-22)	X	QUANTITY OR LOADING (14-15)			QUALITY OR CONCENTRATION (14-15)				NO. EX (17-18)	FREQUENCY OF ANALYSIS (19-20)	SAMPLE TYPE (21-22)	
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS				
00015 4 HEAT MILLIONS OF BTUS PER HR NET EFFLUENT NET		SAMPLE MEASUREMENT	*****	*****		0.00	1735.30	10,922.00		0	Calc	NA
		PERMIT REQUIREMENT	*****	*****		*****	*****	16300.00				*
		SAMPLE MEASUREMENT										
		PERMIT REQUIREMENT										
		SAMPLE MEASUREMENT										
		PERMIT REQUIREMENT										
		SAMPLE MEASUREMENT										
		PERMIT REQUIREMENT										
		SAMPLE MEASUREMENT										
		PERMIT REQUIREMENT										
		SAMPLE MEASUREMENT										
		PERMIT REQUIREMENT										
		SAMPLE MEASUREMENT										
		PERMIT REQUIREMENT										

8111060680 811027
PJR ADDCK 05000272
PDR

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER

P.W. Schneider V.P. Prod.

TYPED OR PRINTED

STATEMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

TOTAL OF DISCH 481,482,483,484,485,486

UPDATED

THIS DOCUMENT IS SIGNED WITH RECOGNITION THAT KNOWINGLY MAKING A FALSE CERTIFICATION ON THIS REPORT OR SUPPORTING DOCUMENTS OR INTENTIONALLY TAMPERING WITH ANY MONITORING DEVICE OR METHOD ARE CRIMINAL OFFENSES. SEE 18 USC § 1001 AND 33 USC § 1319. (Penalties under these statutes may be fines up to \$10,000 and/or maximum imprisonment of between 6 months and 5 years.)

SIGNATURE OF PRINCIPAL EXECUTIVE
OFFICER OR AUTHORIZED AGENT

TELEPHONE

609 365-7000

AREA
CODE

NUMBER

DATE

81 10 22

YEAR MO DAY