

MAILGRAM SERVICE CENTER  
MIDDLETOWN, VA. 22645

western union

Mailgram



1-0029710303 10/30/81 TLX CPCO PARN JKN CGBA  
154 CONSUMERS POWER JACKSON MI

D BOYD  
US NRC  
799 ROOSEVELT RD  
GLEN ELLYN, IL 60137



CPCO PARN JKN  
MSG # WJW343  
THIS CONFIRMS PROMPT NOTIFICATION OF AN OCCURRENCE REPORTABLE  
PER TS 6.9.2.A.9. ON 10/29/81, IT WAS DETERMINED THAT DIESEL  
GENERATOR FUEL OIL DAY TANKS T25A AND T25B MAY NOT BE ABLE TO  
WITHSTAND LOADS IMPOSED BY A SEISMIC EVENT. INITIAL REPORT  
TO H JELLER ON 10/29/81.

G H R PETITJEAN/R W MONTROSS  
CONSUMERS POWER COMPANY  
PALISADES PLANT

09:04 EST

MGMCOMP

8111090656 811030  
PDR ADOCK 05000255  
S PDR

IE29  
NOV 2 1981 s/p