

USNRC REGION II
ATLANTA, GEORGIA
VIRGINIA ELECTRIC AND POWER COMPANY
RICHMOND, VIRGINIA 23261

81 NOV 4 A 9: 54

R. H. LEASBURG
VICE PRESIDENT
NUCLEAR OPERATIONS

October 29, 1981

Mr. James P. O'Reilly, Director
Office of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Region II
101 Marietta Street, Suite 3100
Atlanta, Georgia 30303

Serial No. 604
PSE&C/RHW:lmf
Docket Nos. 50-280
50-281

License Nos. DPR-32
DPR-37

Dear Mr. O'Reilly:

I. E. Bulletin No. 80-11, Masonry Wall Design
Surry Power Station - Units 1 & 2

Enclosed is our final report on I. E. Bulletin No. 80-11 activities at Surry Power Station. The reanalysis indicated in our letter of August 25, 1981 has been completed and the results are included in our final report. This report provides the results of the masonry wall reevaluation program and provides documentation updating our previous submittals. Rather than being comprehensive and resubmitting information previously provided, this report contains a summary of the masonry wall review program and references our previous submittals where more detailed information has been provided.

In summary, the analysis results of the masonry wall reevaluation program for Surry show that 79 walls were acceptable, two walls were acceptable after equipment was removed from the wall, 31 walls were modified, and 7 walls were not acceptable. All of the walls found not to meet the reevaluation criteria required by IE Bulletin 80-11 are located in the Fuel Building. Failure of these walls under extreme seismic or tornado loading would not jeopardize any safety-related equipment as covered by the Station Technical Specifications limiting conditions for operation. The analysis results for the 7 Fuel Building walls were submitted to the NRC in Licensee Event Report No. 81-020/03L-0 by our letter of August 21, 1981, Serial No. 81-047. Our future correspondence on this subject will be in response to the LER rather than I.E. Bulletin 80-11.


8111170338 811029
PDR ADDCK 05000280
Q PDR

IEII

VIRGINIA ELECTRIC AND POWER COMPANY TO Mr. James P. O'Reilly, Director

Should you have any questions or require additional information,
please contact us.

Very truly yours,


H. Leasburg

Enclosure

cc: Mr. Victor Stello, Director
Office of Inspection & Enforcement

COMMONWEALTH OF VIRGINIA)
)
CITY OF RICHMOND)

The foregoing document was acknowledged before me, in and for the City and Commonwealth aforesaid, today by R. H. Leasburg, who is Vice President-Nuclear Operations, of the Virginia Electric and Power Company. He is duly authorized to execute and file the foregoing document in behalf of that Company, and the statements in the document are true to the best of his knowledge and belief.

Acknowledged before me this 29th day of October, 19 81.

My Commission expires: 2-26, 19 85.

Ann C. Moser
Notary Public

(SEAL)