

## (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 3  
7 9 80

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 4

PHONE: (815-942-2920 Ext. 529



# DEVIATION REPORT

Commonwealth Edison

DVR NO. STA UNIT YEAR NO.  
D-12-2-81-115

## PART 1 TITLE OF DEVIATION

Control Rod Drive R-6 Failure to Scram

OCCURRED  
10/17/81 0855  
DATE TIME

SYSTEM AFFECTED 300

PLANT CONDITIONS

CRD

MODE

Run

PWR (MWT)

1255

LOAD (MWE)

371

TESTING  
☒ YES ☐ NO

## DESCRIPTION OF EVENT

CRD (R-6) failed to insert during scram testing. Rod did not move from position "48" by using the individual CRD scram test switch or by pulling the scram solenoid fuses.

## DESCRIPTION OF CAUSE

Failed solenoid

## OTHER APPLICABLE INFORMATION

Control rod was immediately inserted to "00" and electrically disarmed. It will remain at "00" until repaired.

EQUIPMENT ☒ YES  
FAILURE ☐ NO

DR NO. -

WR NO.

D16410

J. R. Doxsey

RESPONSIBLE SUPERVISOR

10/19/81

DATE

## PART 2 OPERATING ENGINEERS COMMENTS

CRD R-6 (58-23) was inserted to position "00", and electrically disarmed. Its symmetrical rods were also inserted to position "00" while repairs were made to CRD R-6 (58-23).

TYPE OF DEVIATION  
REPORTABLE OCCURRENCE

☐ 14 DAY ☐ 10CFR21

☒ 30 DAY NOTIFICATION  
6.6.F.b

EVENT OF POTENTIAL  
PUBLIC INTEREST

☐

TECH SPEC  
VIOLATION

☒

NON-REPORTABLE  
OCCURRENCE

☐

ANNUAL  
REPORTING

YES ☐

NO ☐

SAFETY-  
RELATED  
WR ISSUED

YES ☒

NO ☐

REPORTABLE OCCU  
NUMBER

E

ACTION ITEM NO.

PROMPT ON-SITE NOTIFICATION

R. M. Ragan

10/20/81

TITLE

DATE

TIME

TITLE

DATE

TIME

24-H

(Cont)

RC NOTIFICATION

☒ TTH

T. I

ue

10/19/81

0820

REGION III

DATE

TIME

☐ TGM

REGION III & DOL

DATE

TIME

PROMPT OFF-SITE NOTIFICATION

F. A. Palmer

10/20/81

0815

TITLE

DATE

TIME

TITLE

DATE

TIME

RESPONSIBLE COMPANY OFFICER INFORMED OF 10CFR21  
CONDITIONS AND THEIR REPORT TO NRC

TITLE

DATE

TIME

REVIEW AND COMPLETED

John M. Almer

10/19/81

OPERATING ENGINEER

DATE

ACCEPTANCE BY STATION REVIEW  
AS REQUIRED

DATE

RESOLUTION APPROVED AND  
AUTHORIZED FOR DISTRIBUTION

*J. Brunner*  
11/13/81  
*John M. Almer*  
11/13/81  
*Douglas Burt*  
STATION SUPERINTENDENT

11/13/81  
DATE