NRC FORM 366 (7-77)

LER 81-017/03L-0

U. S. NUCLEAR REGULATORY COMMISSION

LICENSEE EVENT REPORT

CAR 1335

CONTROL BLOCK: (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 | NYRFG1 (2) | 00-0000-00 (3) | 4 (4) | (5)

LICENSEE CODE (7–14) | LICENSE NUMBER (15–25) | LICENSE TYPE (26–30) | CAT (57–58)

CON'T 01 | REPORT SOURCE L (6) | 05000244 (7) | 110810 (8) | 110381 (9)

DOCKET NUMBER (60–68) | EVENT DATE (69–74) | REPORT DATE (75–80)

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 Technical Specification 3.14 requires a 30 day written report if a Fire Suppression
03 system is not restored to service in 14 days with Fire Watch posted. Several Fire
04 Suppression systems have exceeded this 14 day limit. Continuous Fire Watches are
05 being maintained until the systems are restored. These systems have been removed for
06 installation of the Fire System Modifications.
07
08

09 | SYSTEM CODE AB (11) | CAUSE CODE A (12) | CAUSE SUBCODE A (13) | COMPONENT CODE ZZZZZZ (14) | COMP SUBCODE Z (15) | VALVE SUBCODE Z (16)

LER/RO REPORT NUMBER (17): EVENT YEAR 81 | — | SEQUENTIAL REPORT NO. 017 | / | OCCURRENCE CODE 03 | REPORT TYPE L | — | REVISION NO. 0

ACTION TAKEN H (18) | FUTURE ACTION Z (19) | EFFECT ON PLANT Z (20) | SHUTDOWN METHOD Z (21) | HOURS 0000 (22) | ATTACHMENT SUBMITTED N (23) | NPRD-4 FORM SUB. N (24) | PRIME COMP. SUPPLIER Z (25) | COMPONENT MANUFACTURER Z999 (26)

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 The cause for this event was that the Fire System Modifications required by 10CFR50
11 Appendix R removed the system from service during June. The failure to submit a 30
12 day report was due to the Operations Engineer failure to detect the need to issue an
13 LER. All systems shall be returned to service by November 17, 1981.
14

15 | FACILITY STATUS E (28) | % POWER 100 (29) | OTHER STATUS (30) N/A | METHOD OF DISCOVERY A (31) | DISCOVERY DESCRIPTION (32) N/A

16 | ACTIVITY RELEASED Z (33) | CONTENT OF RELEASE Z (34) | AMOUNT OF ACTIVITY (35) N/A | LOCATION OF RELEASE (36) N/A

17 | PERSONNEL EXPOSURES NUMBER 000 (37) | TYPE Z (38) | DESCRIPTION (39) N/A

18 | PERSONNEL INJURIES NUMBER 000 (40) | DESCRIPTION (41) N/A

19 | LOSS OF OR DAMAGE TO FACILITY TYPE Z (42) | DESCRIPTION (43) N/A

20 | PUBLICITY ISSUED Z (44) | DESCRIPTION (45) N/A

8111230340 811113
PDR ADOCK 05000244
S PDR

NRC USE ONLY

NAME OF PREPARER Carl H. Peck

PHONE: 315-524-4446 Ext. 205

GPO 917-326