

CONTROL BLOCK:

--	--	--	--	--	--

0	1	N	Y	J	A	F	1	2	0	0	-	0	0	0	-	0	0	0	3	4	1	1	1	1	4			5	
7	8	LICENSEE CODE						14	15	LICENSE NUMBER										25	LICENSE TYPE					30	57	CAT	58

7 8 60 61 DOCKET NUMBER 68 69 EVENT DATE 74 75 REPORT DATE 80

0 2 | During normal operation, while conducting surveillance to satisfy TS Table 4.2-2,

0 3 | Item 13, condensate storage tank level switch 23-LIS-75B, associated with HPCI

0 4 | suction transfer was damaged and required repair. The other three (3) switches

0 5 | performing the same function were operating normally. No significant hazard

0 6 | existed.

0 7

0 8

80

SYSTEM CODE [0] [3] 7 8		CAUSE CODE [S] [F] (11) 9 10		CAUSE SUBCODE [D] (12) 11		COMPONENT CODE [Z] [Z] [Z] [Z] [Z] [Z] (14) 12 13 14 15 16 17				COMP. SUBCODE [Z] (15) 18 19		VALVE SUBCODE [Z] (16) 20					
(17) LER RO REPORT NUMBER [18] [1] 21 22		EVENT YEAR [18] [1] 21 22		SEQUENTIAL REPORT NO. [0] [7] [3] 23 24 25 26		OCCURRENCE CODE [0] [3] 27 28 29		REPORT TYPE [X] 30		REVISION NO. [1] 31 32							
ACTION TAKEN [X] (18) 33		FUTURE ACTION [G] (19) 34		EFFECT ON PLANT [Z] (20) 35		SHUTDOWN METHOD [Z] (21) 36		HOURS (22) [0] [0] [0] [0] 37 38 39 40		ATTACHMENT SUBMITTED [N] (23) 41		NPRD-4 FORM SUB. [Y] (24) 42		PRIME COMP. SUPPLIER [Z] (25) 43		COMPONENT MANUFACTURER [7] [9] [9] [9] (26) 44 45 46 47	

1 0 Partial disassembly of the instrument enclosure, to allow observation of switch
1 1 action, caused a screw to catch and damage the insulation on a wire. Repair and
1 2 calibration restored the instrument to a fully operable status approximately five
1 3 (5) hours later. In addition, a precaution will be added to the procedure to
1 4 prevent recurrence.

7 8 9 80

FACILITY STATUS (28) % POWER (29) OTHER STATUS (30) METHOD OF DISCOVERY (31) DISCOVERY DESCRIPTION (32)

1 5 E C 7 0 NA B Surveillance

7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50 51 52 53 54 55 56 57 58 59 60

ACTIVITY CONTENT
RELEASED OF RELEASE

1 6 7 33 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50 51 52 53 54 55 56 57 58 59 60 61 62 63 64 65 66 67 68 69 70 71 72 73 74 75 76 77 78 79 80

AMOUNT OF ACTIVITY (39) NA

LOCATION OF RELEASE (36) NA

PERSONNEL EXPOSURES									
NUMBER			TYPE		DESCRIPTION				
1	2	3	4	5	6	7	8	9	10
0	0	0	37	Z	38	NA			

PERSONNEL INJURIES		DESCRIPTION	
NUMBER			
0	0	0	40 NA

8		9		11		12		
LOSS OF OR DAMAGE TO FACILITY						(43)		
TYPE		DESCRIPTION						
1	2	Z	(42)	NA				

8111230438 811113
PDR ADOCK 05000333
PDR

NAME OF PREPARER W. Verne Childs

PHONE 315-342-3840