

CONTROL BLOCK: 

--	--	--	--	--	--

 (1)

0	1	C	O	F	S	V	1	2	0	0	-	0	0	0	0	0	-	0	0	3	4	1	1	2	0	4			5		
7	8	LICENSEE CODE						14	15	LICENSE NUMBER										25	26	LICENSE TYPE					30	57	CAT		58

CON'T

REPORT SOURCE: 01 L 6 050002677 7 1014811 8 11113811 9

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

On three separate occasions, during the period from October 14, 1981, to October 19, 1981, the prestressed concrete reactor vessel cooling water system temperatures exceeded the limits allowed in LCO 4.2.15. This is a degraded mode of the LCO and is reportable per Fort St. Vrain Technical Specification AC 7.5.2(b)2. No accompanying occurrence. Similar RO's 80-46, 81-001, 81-007, and 81-048.

0	7	
---	---	--

0	8		8
7	8	9	

SYSTEM CODE		CAUSE CODE		CAUSE SUBCODE		COMPONENT CODE						COMP. SUBCODE		VALVE SUBCODE								
0	9	C	B	E	E	I	N	S	T	R	U	C	Z									
7	8	9	10	11	12	13	14	15	16	17	18	19	20									
LER/RO REPORT NUMBER		EVENT YEAR		SEQUENTIAL REPORT NO.		OCCURRENCE CODE		REPORT TYPE		REVISION NO.												
17	8	1	—	0	6	2	/	0	3	L	—	0										
21	22	23	24	25	26	27	28	29	30	31	32											
ACTION TAKEN		FUTURE ACTION		EFFECT ON PLANT		SHUTDOWN METHOD		HOURS		ATTACHMENT SUBMITTED		NPRD-4 FORM SUB.		PRIME COMP. SUPPLIER		COMPONENT MANUFACTURER						
B	18	Z	19	Z	20	Z	21	0	0	0	0	Y	23	N	24	N	25	F	1	8	0	26
33	34	35	36	37	38	39	40	41	42	43	44	45	46	47	48	49	50	51	52	53	54	55

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 The controller failure was due to a solder connection under the controllers auto-

1 1 manual relay that failed due to normal usage. System was returned to normal operation

1 2 using a bypass controller. The solder connection was resoldered, and the controller

1 3 tested and returned to service. No further corrective action is anticipated or re-

1 4 quired.

1 5 E 28 0 3 5 29 N/A 30 A 31 Operator Observation 32

ACTIVITY CONTENT  
RELEASED OF RELEASE AMOUNT OF ACTIVITY (35) LOCATION OF RELEASE (36)

1 6 Z 33 Z 34 N/A N/A

PERSONNEL EXPOSURES									
NUMBER			TYPE	DESCRIPTION					
1	7	000	(37) Z	(38) N/A					

7		8		9		11		12		13		80	
PERSONNEL INJURIES													
NUMBER						DESCRIPTION (41)							
1	8	0	0	0	(40)	N/A							

7		8	9	11		12	
LOSS OF OR DAMAGE TO FACILITY						(43)	
TYPE		DESCRIPTION					
1	9	Z	(42)	N/A			

7 8 9 10  
PUBLICITY  
ISSUED DESCRIPTION (45)  
2 0 N (44) N/A  
8111230568 811113  
PDR ADDCK 05000267  
S PDR  
NRC USE ONLY

NAME OF PREPARER

PHONE: (303) 785-2224