

CONTROL BLOCK: | | | | | | | ① (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

CON'T

0	1
---	---

REPORT SOURCE

L	6	0	5	0	0	0	2	6	5	7	1	1	0	3	8	1	8	1	1	2	0	8	1	9
---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---

DOCKET NUMBER

EVENT DATE

REPORT DATE

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 | On November 3, 1981, the HPCI Turbine Area High Temperature switches were calibrated.

0 3 | Temperature switch 2-2373C was found to trip at 209°F which is greater than the

0 4 | Technical Specification Table 3.2-1 limit of less than or equal to 200°F. All other

0 5 | switches tripped within the limit. The switches are arranged in a one-out-of-two-

0 6 | twice logic scheme and initiate a HPCI System isolation when detecting a steam line

0 7 | break in the HPCI Turbine area. One switch out of calibration does not prevent the

0 8 | logic system from performing its function.

09		SYSTEM CODE S D 11		CAUSE CODE E 12		CAUSE SUBCODE E 13		COMPONENT CODE I N S T R U 14						COMP. SUBCODE S 15		VALVE SUBCODE Z 16													
7 8		9 10		11 12		13 14		15 16 17 18						19 20		21 22													
17		EVENT YEAR 6 1		SEQUENTIAL REPORT NO. 0 2 2		OCCURRENCE CODE 0 3		REPORT TYPE L		REVISION NO. 0		ACTION TAKEN E 18		FUTURE ACTION 2 19		EFFECT ON PLANT Z 20		SHUTDOWN METHOD Z 21		HOURS 0 0 0 0 22		ATTACHMENT SUBMITTED N 23		NPRD-4 FORM SUB. Y 24		PRIME COMP. SUPPLIER L 25		COMPONENT MANUFACTURER U 0 7 5 26	
23 24		25 26		27 28		29 30		31 32		33 34		35 36		37 38		39 40		41 42		43 44		45 46		47 48		49 50		51 52	

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 The cause of this occurrence is instrument drift. The switch was recalibrated to

1 1 trip at 186°F. No further corrective action is necessary as this switch has

1 2 shown no adverse drifting trends. These switches are manufactured by United

1 3 Electric Controls, Model Number F-7.

1 4

FACILITY STATUS		% POWER			OTHER STATUS			METHOD OF DISCOVERY		DISCOVERY DESCRIPTION	
1	5	H	28	0	0	0	29	NA	B	31	Routine Testing
7	8	9	10	11	12	13	14	15	16	17	18
ACTIVITY RELEASED		CONTENT OF RELEASE			AMOUNT OF ACTIVITY			LOCATION OF RELEASE			
1	6	Z	33	Z	34	NA	35	NA	36		
7	8	9	10	11	12	13	14	15	16	17	18
PERSONNEL EXPOSURES		NUMBER			TYPE			DESCRIPTION			
1	7	0	0	0	37	Z	38	NA	39		
7	8	9	10	11	12	13	14	15	16	17	18
PERSONNEL INJURIES		NUMBER			DESCRIPTION						
1	8	0	0	0	40	NA	41				
7	8	9	10	11	12	13	14	15	16	17	18
LOSS OF OR DAMAGE TO FACILITY		TYPE			DESCRIPTION						
1	9	Z	42	NA	43						
7	8	9	10	11	12	13	14	15	16	17	18
PUBLICITY ISSUED		DESCRIPTION									
2	0	N	44	NA	45						
7	8	9	10	11	12	13	14	15	16	17	18

8111300412 811120
PDR ADOCK 05000265
S PDR

NRC USE ONLY

NAME OF PREPARER Mike R Steiner

PHONE: 309-654-2241, ext. 192