

LICENSEE EVENT REPORT

EXHIBIT A

CONTROL BLOCK: 1 (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0 1 S C N E E 1 2 0 0 - 0 0 0 0 0 - 0 0 3 4 1 1 1 1 4 5

LICENSEE CODE 14 DOCKET NUMBER 15 EVENT DATE 74 REPORT DATE 30

CON'T

REPORT SOURCE L 5 0 5 0 0 0 2 6 9 7 1 1 0 8 8 1 3 1 1 2 0 8 1 3

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES 10

0 2 On November 8, 1981, an inadvertent release of unsampled water from "A" Laundry and Hot Shower Tank (LHST) occurred. This constitutes a violation of Technical Specification 3.9.8 and is reportable pursuant to Technical Specification 6.6.2.1.a(2). Due to the small amount of water released, the low curie content, and the availability of the Automatic Shutdown Feature on the discharge monitors, it is considered that the health and safety of the public were not affected by this incident.

0 3 M A 11 D 12 Z 13 V A L V E X 14 D 15 D 16

SYSTEM CODE CAUSE CODE CAUSE SUBCODE COMPONENT CODE COMP SUBCODE VALVE SUBCODE

17 8 1 0 2 1 0 1 T 0

LER/RO REPORT NUMBER EVENT YEAR SEQUENTIAL REPORT NO. OCCURRENCE CODE REPORT TYPE REVISION

G 18 Z 19 Z 20 Z 21 0 0 0 0 Y 22 N 24 L 25 G 2 5 5 23

ACTION TAKEN FUTURE ACTION EFFECT ON PLANT SHUTDOWN METHOD HOURS ATTACHMENT SUBMITTED APPROX FORMS PRIME COMP SUPPLIER COMPONENT MANUFACTURER

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS 27

1 0 The apparent cause of the incident was a procedural deficiency in that, for evolutions requiring cross-connecting on LHST with the opposite LHST pump, the operating procedure does not require isolation of the LHST not in use. Immediate corrective action stopped the discharge, and appropriate procedure revisions will be made to prevent recurrence.

1 5 D 28 0 0 0 29 NA 30 A 31 Operator Observation 32

FACILITY STATUS % POWER OTHER STATUS METHOD OF DISCOVERY DISCOVERY DESCRIPTION

1 6 L 33 M 34 5.92 E-5 curies 35 LHST to Keowee tailrace 36

ACTIVITY CONTENT RELEASED OF RELEASE AMOUNT OF ACTIVITY LOCATION OF RELEASE

1 7 0 0 0 37 Z 38 NA 39

PERSONNEL EXPOSURES NUMBER TYPE DESCRIPTION

1 8 0 0 0 40 NA 41

PERSONNEL INJURIES NUMBER DESCRIPTION

1 9 Z 42 NA 43

LOSS OF OR DAMAGE TO FACILITY TYPE DESCRIPTION

2 0 N 44 NA 45

PUBLICITY ISSUED DESCRIPTION

NAME OF PREPARER J. F. Kutzer PHONE: (704) 373-7139

NRC USE ONLY