

TENNESSEE VALLEY AUTHORITY
REGION II
CHATTANOOGA, TENNESSEE 37401 ATLANTA, GEORGIA
400 Chestnut Street Tower II

81 NOV 13 A 8:23
November 9, 1981

BLRD-50-438/81-47
BLRD-50-439/81-50

Mr. James P. O'Reilly, Director
Office of Inspection and Enforcement
U.S. Nuclear Regulatory Commission
Region II - Suite 3100
101 Marietta Street
Atlanta, Georgia



Dear Mr. O'Reilly:

BELLEFONTE NUCLEAR PLANT UNITS 1 AND 2 - TOLERANCE FOR TUBULAR STEEL
CABLE TRAY HANGERS - BLRD-50-438/81-47, BLRD-50-439/81-50 - SECOND
INTERIM REPORT

The subject deficiency was initially reported to NRC-OIE Inspector
R. V. Crlenjak on July 16, 1981 in accordance with 10 CFR 50.55(e) as NCR
1478. This was followed by our first interim report dated August 14,
1981. Enclosed is our second interim report. We expect to submit our
next report by January 28, 1982.

If you have any questions concerning this matter, please get in touch
with R. H. Shell at FTS 858-2688.

Very truly yours,

TENNESSEE VALLEY AUTHORITY

A handwritten signature in cursive script, appearing to read "L. M. Mills".

L. M. Mills, Manager
Nuclear Regulation and Safety

Enclosure

cc: Mr. Victor Stello, Jr., Director (Enclosure)
Office of Inspection and Enforcement
U.S. Nuclear Regulatory Commission
Washington, DC 20555

8112020712 811109
PDR ADOCK 05000438
S PDR

OFFICIAL COPY

IE 27

51/1

ENCLOSURE

BELLEFONTE NUCLEAR PLANT UNITS 1 AND 2
TOLERANCE FOR TUBULAR STEEL CABLE TRAY HANGERS
BLRD-50-438/81-47, BLRD-50-439/81-50
10 CFR 50.55(e)
SECOND INTERIM REPORT

Description of Condition

Because of misunderstanding between the Bellefonte design project and Bellefonte field forces, the field forces fabricated and installed cable tray hangers outside the tolerances allowed by the seismic analysis.

Interim Progress

TVA has identified those supports that were modified outside the tolerances without a Field Change Request to approve the modification. This information, along with a description of each deviation, is being reviewed by TVA on a case-by-case basis. Any modification required to ensure seismic qualification will be made.