

OYSTER CREEK



NUCLEAR GENERATING STATION



Jersey Central Power & Light
Company is a Member of the
General Public Utilities System

(609) 693-6000 P.O. BOX 388 • FORKED RIVER • NEW JERSEY • 08731

November 27, 1981

Director
Office of Nuclear Reactor Regulation
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555



Dear Sir:


Subject: Oyster Creek Nuclear Generating Station
Docket No. 50-219
Alternate Water Supply for Fire Protection System

Amendment No. 38 to the Oyster Creek Operating License and Technical Specifications requires us to complete modifications to the Fire Protection System as specified in the NRC Fire Protection Safety Evaluation and supplements thereto for Oyster Creek. In addition, it requires that in the event these dates cannot be met, the licensee shall submit a report explaining the circumstances together with a revised schedule. Your letter of February 13, 1981, extended the completion date for installation of the alternate water supply tank until November 17, 1981.

In accordance with Amendment No. 38, this letter informs you that the Alternate Water Supply for the fire protection yard loop was made operational at 0130 on November 18, 1981. The delay in meeting our November 17, 1981 commitment was due to difficulties encountered in our pre-operational testing and the resulting modifications which had to be completed prior to declaring the system operational.

If there are any questions, please contact me or Mr. Michael Laggart of my staff at (609) 693-6932.

Very truly yours,


J. T. Carroll, Jr.
Acting Director - Oyster Creek

JTC:MWL:lse

cc: NRC Resident Inspector
Oyster Creek Nuclear Generating Station
Forked River, NJ 08731

A006
S
1/0

8112040522 811127
PDR ADDCK 05000219
F PDR