NRC FORM 366
(7-77)

U. S. NUCLEAR REGULATORY COMMISSION

LICENSEE EVENT REPORT

CONTROL BLOCK: (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 | M D C C N 1 (2) | 0 0 - 0 0 0 0 0 - 0 0 (3) | 4 1 1 1 1 (4) | (5)
LICENSEE CODE — LICENSE NUMBER — LICENSE TYPE — CAT

CON'T
01 | REPORT SOURCE L (6) | 0 5 0 0 0 3 1 7 (7) | 1 0 2 1 8 1 (8) | 1 1 2 0 8 1 (9)
DOCKET NUMBER — EVENT DATE — REPORT DATE

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 | At 0930 during surveillance testing, the hydrogen analyzer sample pump
03 | was found to have a defective bellows rendering the pump inoperable
04 | (T.S. 3.6.5.1). The sample pump was replaced and the system returned to
05 | service at 0930 on October 23, 1981. The redundant hydrogen analyzer
06 | remained operable throughout the event. No similar events have occurred.
07 |
08 |

09 | SYSTEM CODE S E (11) | CAUSE CODE E (12) | CAUSE SUBCODE F (13) | COMPONENT CODE P U M P X X (14) | COMP. SUBCODE X (15) | VALVE SUBCODE Z (16)

(17) LER RO REPORT NUMBER: EVENT YEAR 8 1 | — | SEQUENTIAL REPORT NO. 0 7 6 | / | OCCURRENCE CODE 0 3 | REPORT TYPE L | — | REVISION NO. 0

ACTION TAKEN C (18) | FUTURE ACTION Z (19) | EFFECT ON PLANT Z (20) | SHUTDOWN METHOD Z (21) | HOURS (22) 0 0 0 0 | ATTACHMENT SUBMITTED N (23) | NPRD-4 FORM SUB. Y (24) | PRIME COMP. SUPPLIER A (25) | COMPONENT MANUFACTURER M 2 7 0 (26)

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 | The pump (Metal Bellows MB118) bellows was found broken in what is con-
11 | sidered a natural end of life type of failure. The pump is original
12 | plant equipment; no similar failures have occurred. The pump will soon
13 | be replaced by new equipment being installed to meet requirements of
14 | NUREG 0578. The sample pumps are surveillance-tested quarterly.

15 | FACILITY STATUS E (28) | % POWER 0 9 0 (29) | OTHER STATUS (30) NA | METHOD OF DISCOVERY B (31) | DISCOVERY DESCRIPTION (32) Surveillance Testing

16 | ACTIVITY RELEASED Z (33) | CONTENT OF RELEASE Z (34) | AMOUNT OF ACTIVITY (35) NA | LOCATION OF RELEASE (36) NA

17 | PERSONNEL EXPOSURES NUMBER 0 0 0 (37) | TYPE Z (38) | DESCRIPTION (39) NA

18 | PERSONNEL INJURIES NUMBER 0 0 0 (40) | DESCRIPTION (41) NA

19 | LOSS OF OR DAMAGE TO FACILITY TYPE Z (42) | DESCRIPTION (43) NA

20 | PUBLICITY ISSUED N (44) | DESCRIPTION (45) NA

8112040606 811120
PDR ADOCK 05000317
S PDR

NRC USE ONLY

NAME OF PREPARER M.A. Junge/P.G. Rizzo PHONE: 301-269-4969/4786

GPO 917-926