



Log # TXX-90088
File # 10119
Ref. # NRCB 88-05

March 2, 1990

William J. Cahill, Jr.
Executive Vice President

U. S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, D. C. 20555

SUBJECT: COMANCHE PEAK STEAM ELECTRIC STATION (CPSES)
DOCKET NOS. 50-445 AND 50-446
REQUEST FOR ADDITIONAL INFORMATION ON RESPONSE TO
NRC BULLETIN 88-05 AND SUPPLEMENTS 1 AND 2

- REF: 1) TU Electric letter from Mr. W. J. Cahill, Jr. to
U. S. NRC dated January 11, 1989, TXX-89005
- 2) TU Electric letter from Mr. W. J. Cahill, Jr. to
U. S. NRC dated March 31, 1989, TXX-89163
- 3) TU Electric letter from Mr. W. J. Cahill, Jr. to
U. S. NRC dated January 26, 1990, TXX-90039
- 4) TU Electric letter from Mr. W. J. Cahill, Jr. to
U. S. NRC dated February 2, 1990, TXX-90059

Gentlemen:

TU Electric responded to NRC Bulletin 88-05 "Nonconforming Material Supplied by Piping Supplies, Inc. at Folsom, New Jersey and West Jersey Manufacturing Company at Williamstown, New Jersey" as modified by Supplements 1 and 2, by TXX-89005, dated January 11, 1989 (Reference 1) and TXX-89163, dated March 31, 1989 (Reference 2). TU Electric also responded to a NRC request for additional information on this subject by TXX-90039, dated January 26, 1990 (Reference 3) and TXX-90059, dated February 2, 1990 (Reference 4). Based on further discussions with NRC personnel on this subject, the following additional information is provided.

TU Electric has reviewed its records/documentation to identify WJM/PSI/CLM material installed in the ASME Boiler and Pressure Vessel Code, Section III, Division 1, Code Class 1 piping systems. The review revealed that no WJM/PSI/CLM material was supplied to, or installed, in any ASME

9003120807 900302
PDR ADOCK 05000445
Q PDC

TE 11

TXX-90088
Page 2 of 2
March 2, 1990

Code Class 1 piping systems for CPSES Unit 1.

Additional information based on the results of a CPSES Unit 2 review of location, identification and testing of WJM/PSI/CLM material will be provided prior to Unit 2 fuel load.

Sincerely,

William J. Cahill, Jr.

William J. Cahill, Jr.

By: *Roger D. Walker*
Roger D. Walker
Manager, Nuclear Licensing

MCP/vld

c - Mr. R. D. Martin, Region IV
Resident Inspectors, CPSES (3)