

ATTACHMENT C

OFF-SITE PROCEDURE NOTIFICATION FORM

DATE: THURSDAY, MARCH 22, 1990

DISTRIBUTE TO: US NUCLEAR REG COMM

Please REMOVE the following pages from your controlled copy of the LaSalle County Station Procedures Manual. INSERT the new pages as indicated and REMOVE and DESTROY the superseded pages. SIGN this transmittal form in the space provided for Manual holder below. RETURN this signed sheet to:

Central File Supervisor  
LaSalle County Station

Station Manager  
LaSalle County Station

SET NUMBER: 97

-----  
MANUAL HOLDER SIGNATURE DATE  
(IF NEW HOLDER, PLEASE ADVISE.)

DOCUMENT	REMOVE REV #	INSERT REV #	DATE
INDEX	OLD	NEW	
LZP-1320-1	33	34	03/07/90

9004100406 900307  
PDR ADOCK 05000373  
F PDC

A045  
0/1

10/02/89

## LZP INDEX

Page 1

PROC. NO.	TITLE	REV.	DATE
LZP-100-1	DELETED	03	11/80
LZP-100-2	DELETED	04	11/80
LZP-100-3	DELETED	03	10/80
LZP-100-4	DELETED	02	11/80
LZP-200-2	DELETED	02	11/80
LZP-200-3	DELETED	02	11/80
LZP-200-4	DELETED	03	11/80
LZP-210-1	DELETED	02	10/80
LZP-300-1	DELETED	04	8/80
LZP-300-2	DELETED	03	11/80
LZP-310-1	DELETED	03	11/80
LZP-320-1	DELETED	02	10/80
LZP-330-1	DELETED	01	10/80
LZP-340-1	DELETED	01	10/80
LZP-350-1	DELETED	02	10/80
LZP-360-1	DELETED	02	10/80
LZP-370-1	DELETED	01	10/80
LZP-400-1	DELETED	02	11/80
LZP-400-2	DELETED	02	10/80
LZP-400-3	DELETED	01	11/80
LZP-410-1	DELETED	01	11/80
LZP-420-1	DELETED	01	11/80
LZP-510-1	DELETED	02	10/80
LZP-520-1	DELETED	02	10/80
LZP-520-2	DELETED	01	10/80

ZWINDEX

10/02/89

## LZP INDEX

Page 2

PROC. NO.	TITLE	REV.	DATE
LZP-520-3	DELETED	01	10/80
LZP-530-1	DELETED	01	10/80
LZP-530-2	DELETED	02	10/80
LZP-540-1	DELETED	01	10/80
LZP-700-2	DELETED	01	11/80
LZP-710-1	DELETED	02	10/80
LZP-810-1	DELETED	01	10/80
LZP-820-1	DELETED	01	10/80
LZP-830-1	DELETED	01	10/80
LZP-850-1	DELETED	01	10/80
LZP-860-1	DELETED	01	10/80
LZP-880-1	DELETED	01	11/80
LZP-1110-1	STATION DIRECTOR (ACTING STATION DIRECTOR) IMPLEMENTING PROCEDURE	14	1/90
LZP-1110-2	STATION DIRECTOR'S COMMUNICATOR IMPLEMENTING PROCEDURE	00	4/87
LZP-1120-1	OPERATIONS DIRECTOR IMPLEMENTING PROCEDURE	06	3/86
LZP-1120-2	OPERATIONAL SUPPORT CENTER DIRECTOR IMPLEMENTING PROCEDURE	02	7/87
LZP-1120-3	OPERATIONAL SUPPORT CENTER SUPERVISOR IMPLEMENTING PROCEDURE	00	4/87
LZP-1130-1	TECHNICAL DIRECTOR IMPLEMENTING PROCEDURE	06	4/87
LZP-1140-1	MAINTENANCE DIRECTOR IMPLEMENTING PROCEDURE	03	4/87
LZP-1150-1	STORES DIRECTOR IMPLEMENTING PROCEDURE	03	4/87
LZP-1160-01	ADMINISTRATIVE DIRECTOR IMPLEMENTING PROCEDURE	06	12/88
LZP-1170-1	SECURITY DIRECTOR IMPLEMENTING PROCEDURE	09	12/89
LZP-1170-2	ASSEMBLY AND EVACUATION OF PERSONNEL	00	8/87

ZWINDEX

PROC. NO.	TITLE	REV.	DATE
LZP-1180-1	RAD/CHEM DIRECTOR IMPLEMENTING PROCEDURE	06	4/87
LZP-1180-2	DELETED	05	3/86
LZP-1190-01	TSC ENVIRONS DIRECTOR IMPLEMENTING PROCEDURE	02	5/87
LZP-1200-1	CLASSIFICATION OF GSEP CONDITIONS	09	1/90
LZP-1200-2	DELETED	05	5/88
LZP-1200-3	DELETED	03	8/88
LZP-1200-4	DELETED	03	8/88
LZP-1200-5	GSEP GUIDELINES FOR RECOMMENDED OFFSITE PRO- TECTIVE ACTIONS	04	6/89
LZP-1210-1	REPORTING HAZARDOUS MATERIAL INCIDENTS AND OTHER MAJOR TROUBLE	09	12/89
LZP-1210-2	NUCLEAR ACCIDENT REPORTING SYSTEM (NARS) FORM	02	6/89
LZP-1220-1	EMERGENCY TELEPHONE NUMBER	01	5/81
LZP-1220-4	DELETED	01	7/81
LZP-1250-1	A-MODEL OPERATION	00	3/88
LZP-1250-3	A-MODEL INFORMATIONAL MESSAGES	00	8/88
LZP-1310-1	NOTIFICATIONS	17	1/90
LZP-1320-1	AUGMENTATION OF PLANT STAFFING	34	3/90
LZP-1320-2	OPERATIONAL CHECK OF THE GSEP ACTIVATION PHONE LIST	02	5/88
LZP-1330-1	DELETED	02	7/82
LZP-1330-2	DELETED	02	7/82
LZP-1330-3	DELETED	03	7/82
LZP-1330-4	DELETED	02	7/82
LZP-1330-5	DELETED	01	8/86
LZP-1330-6	DELETED	01	7/81
LZP-1330-7	DELETED	02	7/82

## AUGMENTATION OF PLANT STAFFING

### A. PURPOSE

The purpose of this procedure is to outline the steps necessary to meet personnel needs for various GSEP conditions.

### B. REFERENCES

1. Generating Stations Emergency Plan.
2. LZP-1110-1, "Station Director (Acting Station Director) Implementing Procedure".
3. LZP-1170-1, "Security Director Implementing Procedures.
4. NO Directive NOD-EP.2, "GSEP Training Program for Qualified GSEP Participants".
5. LAP-1100-21, "Commonwealth Edison Call-outs for Unscheduled Work".

### C. PREREQUISITES

1. None.

### D. PRECAUTIONS

1. None.

### E. LIMITATIONS AND ACTIONS

1. Attachment B shall be reviewed and updated quarterly, in accordance with Reference 1.
2. In an actual emergency, trainees may be used on a temporary basis to alleviate the emergency and enhance the health and safety of employees or the public. Their use must be approved by the Station Director, Corporate Command Center Director or Manager of Emergency Operations in accordance with Reference 4.
3. Call-outs for GSEP Augmentation should be handled in accordance with Reference 5.

### F. PROCEDURE

1. As outlined in Attachment B, the acting Station Director will activate the GSEP Station Group Directors as follows:
  - a. Transportation accident - as deemed appropriate.

ZWLZP



- b. Unusual Event - notification of individuals indicated in Attachments A and B and others as deemed appropriate.
- c. Alert - activation of individuals indicated in Attachments A and B and others as deemed appropriate.
- d. Site emergency - GSEP Station Group within 60 minutes (See Attachments A, B and C).
- e. General emergency - GSEP Station Group within 60 minutes (See Attachments A, B, and C).

NOTE

The GSEP Station Director, Operations Director, and Maintenance Director are always notified.

- 2. Use Attachment C for the purpose of Station Group notifications.
- 3. Station Group Directors shall perform duties as deemed necessary and fill the manpower requirements needed by the use of the Station Employee List.
- 4. If additional personnel are required beyond those available from the station employee list, the Station Director may request personnel from other C.E.Co. nuclear stations, divisions, general office, or contractors through the Corporate Command Center Director.

G. CHECKLISTS

- 1. None.

H. TECHNICAL SPECIFICATION REFERENCES

- 1. None.

ATTACHMENT A

GUIDANCE FOR AUGMENTATION OF THE ONSITE  
EMERGENCY ORGANIZATION WITHIN 60 MINUTES

Augmentation Within 60 Minutes			
Functional Area	Unusual Event	Alert	Site & General Emergency
1. Command & Control	<u>Notification Only</u>		
Station Director	1	1	1
Oper. Director	1	1	1
Maint. Director	1	1	1
Tech. Director	*1	1	1
Admin. Director	*1	1	1
Stores Director	*1	1	1
Rad/Chem Director	*1	1	1
Security Director	*1	1	1
Environs Director	*1	1	1
OSC Director	*1	1	1
2. Notifications & Communications		#1-5	5
3. Accident Assessment			
Offsite		*2	4
Onsite		*1	1
In-Plant		*1	1
Rad/Chem (Lab)		*1	1
4. Technical Support			
Nuclear (Core)		*1	1
Electrical		*1	1
Mechanical		*1	1
5. Repair & Correction			
Mechanical		*1	1
Electrical		*1	1
Radwaste		*1	1
Inst. & Control		*1	1
6. Protective Actions			
Radiation Protection		*2	4
	*3-10	*11-29	33

\*As needed depending upon the nature of the emergency.

#Min. of one required, LaSalle Station may augment with up to 5 for full manning of phone and status boards at Alert..

NOTE: Additional support in the areas of Command & Control; Communications; and Accident Assessment will be available from the Corporate Command Center Staff. It is reasonable to expect partial manning of the CCC within 60 minutes for the Site & General Emergencies.

ZWLZP

ATTACHMENT B  
INITIAL NOTIFICATIONS AND GESP  
ACTIVATION PHONE LIST  
(Shift Engineer/Station Director)  
\*Reviewed every calendar quarter.

I. UNUSUAL EVENT OR TRANSPORTATION ACCIDENT.

- A. Notify System Power Dispatcher, Illinois Emergency Services and Disaster Agency (ESDA) and Illinois (DNS) on the NARS phone (Code 20).
- B. Notify NRC Operations Center by way of the Emergency Notification System (ENS). If the ENS network is disabled the alternative methods of notification listed below should be attempted in the order given.

<u>TELEPHONE SYSTEM</u>	<u>TELEPHONE NUMBER</u>
1. Commercial Telephone System to NRC Operations Center	301-951-0550 301-427-4056 301-427-4259 301-492-8893
2. Health Physics Network to NRC Operations Center (from the TSC)	301-951-1212 301-951-6000

NOTE

NRC Region III may be contacted as necessary on Red Phone or by calling 708-790-5500.

(Unusual Event or Transportation Accident notification requirements are continued on the following page.)



ATTACHMENT B (Cont.)

C. Notify Operations Director, Station Director, and Maintenance Director.

Name	Office Ext.	Home Phone	Off-site Pager
<u>Operations Director (Contact 1)</u>			
Joseph V. Schmeltz	2681	815-672-3779	112649
John H. Atchley	2215	815-496-9205	
* Johnny E. Lockwood	2549	815-942-9646	
* Herbert J. Hentschel	2217	815-942-6586	
<u>Station Director (Contact 1)</u>			
Gerald J. Diederich	2212	815-942-5440	321670
William R. Huntington	2214	815-433-5541	111815
John C. Renwick	2213	815-744-3746	111055
* David S. Berkman	2734	815-433-2518	111914
<u>Maintenance Director (Contact 1)</u>			
William E. Sheldon	2221	815-942-1183	110833
* Martin G. Santic	2289	815-942-9289	105941
* Ronald D. Crawford	2223	815-357-6588	

NOTE

The off-site page access number is 1-800-621-0985.

D. Notify local agencies (i.e., fire department, hospitals, etc.) as appropriate.

\* Indicates Trainee.

ATTACHMENT B (Cont.)

II. ALERT OR SITE EMERGENCY.

- A. Notify System Power Dispatcher, Illinois ESDA and Illinois DNS (if Corporate Command Center not manned) on the NARS phone (Code 20).
- B. Notify NRC Operations Center by way of the Emergency Notification System (ENS). If the ENS network is disabled the alternative methods of notification listed below should be attempted in the order given.

<u>TELEPHONE SYSTEM</u>	<u>TELEPHONE NUMBER</u>
1. Commercial Telephone System to NRC Operations Center	301-951-0550 301-427-4056 301-427-4259 301-492-8893
2. Health Physics Network to NRC Operations Center (from the TSC)	301-951-1212 301-951-6000

NOTE

NRC Region III may be contacted as necessary on Red phone or by calling 708-790-5500.

- C. Activate Station GSEP Directors by use of the public address system and the intraplant radio system. During other than normal working hours notify the Operations Duty Supervisor to activate Station Group and required augmentation.

NOTE

If a SITE EMERGENCY is declared prior to TSC Staffing, then the Acting Station Director is responsible for sounding the assembly siren and accounting for site personnel (LZP 1170-1 Security Director).

Name

Home Phone

Operations Duty Supervisor - Initiates call tree (Attachment C)

John H. Atchley	815-496-9205	
Johnny E. Lockwood	815-942-9646	
Joseph V. Schmeltz	815-672-3779	
Herbert J. Hentschel	815-942-6586	
Off-Site Pager	1-800-621-0985	110255

- D. Notify local agencies as appropriate.

ZWLZP

ATTACHMENT B (Cont.)

III. GENERAL EMERGENCY.

- A. Notify System Power Dispatcher, Illinois ESDA and Illinois DNS (If Corporate Command Center is not manned) on the NARS phone (Code 20 unless the General Emergency is the initiating event, then use Code 25).
- B. Notify NRC Operations Center by way of the Emergency Notification System (ENS). If the ENS network is disabled the alternative methods of notification listed below should be attempted in the order given.

<u>TELEPHONE SYSTEM</u>	<u>TELEPHONE NUMBER</u>
1. Commercial Telephone System to NRC Operations Center	301-951-0550 301-427-4056 301-427-4259 301-492-8893
2. Health Physics Network to NRC Operations Center (from the TSC)	301-951-1212 301-951-6000

NOTE

NRC Region III may be contacted as necessary on Red Phone or by calling 708-790-5500.

- C. Activate Station GSEP Directors by use of the public address system and the intraplant radio system. During other than normal working hours notify the Operations Duty Supervisor to activate Station Group and required augmentation.

<u>Name</u>	<u>Home Phone</u>
<u>Operations Duty Supervisor</u> - Initiates call tree (Attachment C)	
John H. Atchley	815-496-9205
Johnny E. Lockwood	815-942-9646
Joseph V. Schmeltz	815-672-3779
Herbert J. Hentschel	815-942-6586
Off-Site Pager	1-800-621-0985 110255

- D. Notify local agencies as appropriate.

ATTACHMENT C

CALL TREE SEQUENCE (ALERT, SITE EMERGENCY OR GENERAL EMERGENCY)

Acting Station Director/Station Director

↓

Operating Duty Supervisor

↓

Call List A

Maintenance GSEP Caller---

Operating Director

Station Director

Call List B

Tech Staff GSEP Caller--→

Technical Director

Maintenance Director

R/C Director

Environs Director

Mechanical

Electrical

Radwaste

Inst. and Control

Call List C

R/C GSEP Caller----→

Security Director

Admin Director

Stores Director

Sta. Dir. Communicators

Communicators

Nuclear Support

Electrical Support

Mechanical Support

Call List D

OSC Supervisor

R/C Lab

Environs Team Leaders

Rad. Prot. Techs.

Chemistry Techs.

ATTACHMENT C (Cont.)  
CALL LIST A

OPERATIONS DUTY SUPERVISOR CALLS THE FOLLOWING:

1. Contact a Maintenance GSEP Caller and pass the following message:

"This is a GSEP Augmentation Call. Have you consumed alcohol in the past five hours?" (If YES, continue with the next question. If NO, continue with the appropriate GSEP message below.)

"Are you able to make GSEP Telephone Calls?" (If YES, continue with the appropriate GSEP message below. If NO, terminate the call and move on.

GSEP Message: LaSalle Station has declared a(n) \_\_\_\_\_  
(Alert, Site Emergency or General Emergency).  
Initiate Call List B immediately.

Maintenance GSEP Callers (Contact 1 at Alert, Site Emergency or General Emergency)

<u>Name</u>	<u>Home Phone</u>
Thomas Proska	815-433-4279
Mark Smith	815-249-6665
William Halcott	815-672-6244

2. Contact an Operations Director and a Station Director and pass the following message:

"This is a GSEP Augmentation Call. Have you consumed alcohol in the past five hours?" (If YES, continue with the next question. If NO, continue with the appropriate GSEP message below.)

"Are you able to come in?" (If YES, continue with the appropriate GSEP message below. If NO, terminate the call and move on.

GSEP Message: LaSalle Station has declared a(n) \_\_\_\_\_  
(Alert, Site Emergency or General Emergency).  
Report to the Technical Support Center Immediately.

Operations Directors (Contact 1 at Alert, Site Emergency or General Emergency)

<u>Name</u>	<u>Home Phone</u>
Joseph V. Schmeltz	815-672-3779
John H. Atchley	815-496-9205
* Johnny E. Lockwood	815-942-9646
* Herbert J. Hentschel	815-942-6586

ZWLZP



ATTACHMENT C (Cont.)  
CALL LIST A (Cont.)

Station Directors (Contact 1 at Alert, Site Emergency or General Emergency)

<u>Name</u>	<u>Home Phone</u>	<u>Offsite Pager</u>
Gerald J. Diederich	815-942-5440	321670
William R. Huntington	815-433-5541	111815
John C. Renwick	815-744-3746	111055
* David S. Berkman	815-433-2518	111914

NOTE

The Offsite Pager phone number is 1-800-621-0985.

4. Record the names of the respondents on Attachment D.
5. Report completion of the Call List to the Shift Engineer.
6. Call Security (extension 2496 or 2616) to arrange for breath analysis for any individual who has consumed alcohol five hours prior to reporting to the TSC.

ATTACHMENT C (Cont.)  
CALL LIST B

MAINTENANCE GSEP CALLER CALLS THE FOLLOWING:

1. Contact a Tech. Staff GSEP Caller and pass the following message:

"This is a GSEP Augmentation Call. Have you consumed alcohol in the past five hours?" (If YES, continue with the next question. If NO, continue with the appropriate GSEP message below.)

"Are you able to make GSEP Telephone Calls?" (If YES, continue with the appropriate GSEP message below. If NO, terminate the call and move on.

GSEP Message: LaSalle Station has declared a(n) \_\_\_\_\_  
(Alert, Site Emergency or General Emergency).  
Initiate Call List C immediately.

Tech Staff GSEP Callers (Contact 1 at Alert, Site Emergency or General Emergency)

<u>Name</u>	<u>Home Phone</u>
Michael Martinovich	815-433-4934
Harold Vinyard	815-942-6557
Charles Sprunger	815-942-6576

2. Contact a Technical Director, Maintenance Director, Rad/Chem Director, and an Environs Director and pass the following message:

"This is a GSEP Augmentation Call. Have you consumed alcohol in the past five hours?" (If YES, continue with the next question. If NO, continue with the appropriate GSEP message below.)

"Are you able to come in?" (If YES, continue with the appropriate GSEP message below. If NO, terminate the call and move on.

GSEP Message: LaSalle Station has declared a(n) \_\_\_\_\_  
(Alert, Site Emergency or General Emergency).  
Report to the Technical Support Center Immediately.

Technical Directors (Contact 1 at Alert, Site Emergency or General Emergency)

<u>Name</u>	<u>Home Phone</u>	<u>Offsite Pager</u>
Jeffery Miller	815-795-6013	
Richard Shields	815-433-4544	
Michael Martinovich	815-433-4934	
James Gieseke	815-725-3647	
Thomas Hammerich	815-883-9103	107351

ZWLZP

ATTACHMENT C (Cont.)  
CALL LIST B (Cont.)

Maintenance Directors (Contact 1 at Alert, Site Emergency or General  
Emergency)

Name	Home Phone	Offsite Pager
William Sheldon	815-942-1183	110833
* Martin Santic	815-942-9289	105941
* Ronald Crawford	815-357-6588	105595

Rad/Chem Directors (Contact 1 at Alert, Site Emergency or General  
Emergency)

Name	Home Phone	Offsite Pager
Joseph Lewis	815-795-5881	106535
Dennis Hieggelke	815-434-7110	108854
* Mark Friedmann	815-942-6878	

Environs Directors (Contact 1 at Alert, Site Emergency or General  
Emergency)

Name	Home Phone	Offsite Pager
Timothy Greene	815-942-3643	
Michael Hayworth	815-942-0125	136326
Karl Klotz	708-416-8240	
* Timothy Popp	815-434-1012	

NOTE

The Offsite Pager phone number is 1-800-621-0985.

3. Contact one each of the Repair and Correction Mechanical, Electrical, Radwaste and Instrument and Control and pass the following message:

"This is a GSEP Augmentation Call. Have you consumed alcohol in the past five hours?" (If YES, continue with the next question. If NO, continue with the appropriate GSEP message below.)

"Are you able to come in?" (If YES, continue with the appropriate GSEP message below. If NO, terminate the call and move on.

GSEP Message: LaSalle Station has declared a(n) \_\_\_\_\_  
(Alert, Site Emergency or General Emergency).  
Report to the Technical Support Center Immediately.

ATTACHMENT C (Cont.)  
CALL LIST B (Cont.)

Repair and Correction Mechanical (Contact 1 at Alert, Site Emergency or  
General Emergency)

<u>Name</u>	<u>Home Phone</u>
Raymond Burke	815-434-5795
Michael Young	815-634-8554
William Halcott	815-672-6244

Repair and Correction Electrical (Contact 1 at Site Emergency or General  
Emergency)

<u>Name</u>	<u>Home Phone</u>
James Hamrick	815-357-8060
William Petrick	815-942-6581
Douglas Pedersen	815-584-1325

Repair and Correction Radwaste (Contact 1 at Site Emergency or General  
Emergency)

<u>Name</u>	<u>Home Phone</u>
Keith Francis	815-673-1432
Jack Andrews	815-433-0890
Alan Bailey	815-942-3042
Karl Bowker	815-436-2966

Repair and Correction Instrument and Control (Contact 1 at Site Emergency  
or General Emergency)

<u>Name</u>	<u>Home Phone</u>	<u>Offsite Pager</u>
Michael Cray	815-586-4553	105660
Alan Trainor	815-584-1379	
William Bejlovec	815-725-7380	123373
Kenneth Presley	815-634-2539	

NOTE

The Offsite Pager phone number is 1-800-621-0985.

- Record the names of the respondents on Attachment D.
- Report completion of the Call List to the Shift Engineer.
- Call Security (extension 2496 or 2616) to arrange for breath analysis for any individual who has consumed alcohol five hours prior to reporting to the TSC.

ZWLZP



ATTACHMENT C (Cont.)  
CALL LIST C

TECH STAFF GSEP CALLER CALLS THE FOLLOWING:

1. Contact a Rad/Chem GSEP Caller and pass the following message:

"This is a GSEP Augmentation Call. Have you consumed alcohol in the past five hours?" (If YES, continue with the next question. If NO, continue with the appropriate GSEP message below.)

"Are you able to make GSEP Telephone Calls?" (If YES, continue with the appropriate GSEP message below. If NO, terminate the call and move on.

GSEP Message: LaSalle Station has declared a(n) \_\_\_\_\_  
(Alert, Site Emergency or General Emergency).  
Initiate Call List D immediately.

Rad/Chem GSEP Callers (Contact 1 at Alert, Site Emergency or General Emergency)

<u>Name</u>	<u>Home Phone</u>
Scott Wilkinson	815-942-1041
William Duttlinger	815-883-3669
David Rhoades	815-434-1909

2. Contact a Security Director, Administrative Director, Stores Director, Station Director's Communicator, Communicators, Technical Support Nuclear, Technical Support Electrical, and Technical Support Mechanical and pass the following message:

"This is a GSEP Augmentation Call. Have you consumed alcohol in the past five hours?" (If YES, continue with the next question. If NO, continue with the appropriate GSEP message below.)

"Are you able to come in?" (If YES, continue with the appropriate GSEP message below. If NO, terminate the call and move on.

GSEP Message: LaSalle Station has declared a(n) \_\_\_\_\_  
(Alert, Site Emergency or General Emergency).  
Report to the Technical Support Center Immediately.



ATTACHMENT C (Cont.)  
CALL LIST C (Cont.)

Security Directors (Contact 1 at Alert, Site Emergency or General  
Emergency)

<u>Name</u>	<u>Home Phone</u>	<u>Offsite Pager</u>
David Stapleton	815-434-7818	
George Hacke	815-942-4432	
Richard Morley	815-942-6697	106577
Dale Waldschmidt	815-741-2816	

Administrative Directors (Contact 1 at Alert, Site Emergency or General  
Emergency)

<u>Name</u>	<u>Home Phone</u>
Richard Klemp	815-357-6403
Ray Dillon	815-634-2057
Alice Norris	815-741-4556

Stores Director (Contact 1 at Alert, Site Emergency or General Emergency)

<u>Name</u>	<u>Home Phone</u>	<u>Offsite Pager</u>
Susan Laughlin	815-942-6632	106618
Patrick Clift	815-672-0967	043068
Leonard Bruce	815-357-8743	108763

Station Director's Communicator (Contact 1 at Alert, Site Emergency or  
General Emergency)

<u>Name</u>	<u>Home Phone</u>
Samuel Harmon	815-433-1031
Robert Roy	815-433-3642
Jerry Houston	815-434-2179

Communicators (Contact 1 at Alert. Contact 5 at Site Emergency or General  
Emergency)

<u>Name</u>	<u>Home Phone</u>
David Sheldon	815-434-1872
Larry Blunk	815-433-1299
Grady Teeter	815-357-8044
James Fulton	815-672-6765
Patricia Sensiba	815-433-5073
Jeff Beck	815-942-9541
Robert Simers	815-942-0356
Kim Keutzer	815-224-4781
Gil Bucio	815-941-2033
John Thunstedt	815-935-2321
Joseph Hughes	815-434-5207

ATTACHMENT C (Cont.)  
CALL LIST C (Cont.)

Technical Support Nuclear (Contact 1 at Site Emergency or General  
Emergency)

<u>Name</u>	<u>Home Phone</u>
Edward McVey	815-942-9256
Gary Benes	815-942-6778
David Henry	708-416-9304

Technical Support Electrical (Contact 1 at Site Emergency or General  
Emergency)

<u>Name</u>	<u>Home Phone</u>	<u>Offsite Pager</u>
Dale Spencer	815-795-5891	135956
Harold Vinyard	815-942-6557	
James Peters	815-744-7597	

Technical Support Mechanical (Contact 1 at Site Emergency or General  
Emergency)

<u>Name</u>	<u>Home Phone</u>
Dave Lyon	815-844-7439
Michael Entwistle	815-883-8062

NOTE

The Offsite Pager phone number is 1-800-621-0985.

3. Record the names of the respondents on Attachment D.
4. Report completion of the Call List to the Shift Engineer.
5. Call Security (extension 2496 or 2616) to arrange for breath analysis for any individual who has consumed alcohol five hours prior to reporting to the TSC.

ATTACHMENT C (Cont.)  
CALL LIST D

RAD/CHEM GSEP CALLER CALLS THE FOLLOWING:

1. Contact a OSC Supervisor, Rad/Chem Lab Support, Environs Field Team Leaders, Radiation Protection Technicians and Chemistry Technicians and pass the following message:

"This is a GSEP Augmentation Call. Have you consumed alcohol in the past five hours?" (If YES, continue with the next question. If NO, continue with the appropriate GSEP message below.)

"Are you able to come in?" (If YES, continue with the appropriate GSEP message below. If NO, terminate the call and move on.

GSEP Message: LaSalle Station has declared a(n) \_\_\_\_\_  
(Alert, Site Emergency or General Emergency).  
Report to the Technical Support Center Immediately.

OSC Supervisors (Contact 1 at Site Emergency or General Emergency)

<u>Name</u>	<u>Home Phone</u>
Charles Magistro	815-357-8814
Larry Bryant	815-433-3566
Terrance Riner	815-584-3090
Paul Knoll	815-434-1710
Kenneth Zitzke	815-433-2142
James Dietz	815-725-8151

Chem Lab Support (Contact 1 at Site Emergency or General Emergency)

<u>Name</u>	<u>Home Phone</u>	<u>Offsite Pager</u>
Robert Sayers	815-634-2664	
James Schuster	815-942-8477	
Paul Nottingham	815-942-4788	108680
Joseph Terrones	815-433-3958	

Environs Field Team Leaders (Contact 2 at Site Emergency or General Emergency)

<u>Name</u>	<u>Home Phone</u>
Charles Magistro	815-357-8814
Ross Rod	815-433-5634
Toby Hodges	815-434-1906
Larry Bryant	815-433-3566
Clyde Kelley	815-433-5756
Paul Knoll	815-434-1710
Terrance Riner	815-584-3090
Kenneth Zitzke	815-433-2142
Kenneth Watson	815-942-1412
Terry R. Gibes	815-838-4215
James E. Dietz	815-725-8151

ATTACHMENT C (Cont.)  
CALL LIST D (Cont.)

Radiation Protection Technicians (Contact 5 at Site Emergency or General  
Emergency)

<u>Name</u>	<u>Home Phone</u>
Kevin Hedgspeth	815-643-2579
Darrell Hovious	815-795-5077
Mike Close	815-795-5781
John Cuffe	815-434-1621
Mark Ingold	815-433-9406
David Sergenti	815-434-2712
Mike Wakely	815-433-4745
James Kein	815-434-3248
Neil Hightower	815-673-3691
Lou Hancin	815-673-1828
James Page	815-672-8397
William Risley	815-672-9545
Thomas Smith	815-672-3357
Gregory Smith	815-586-4278
David Cooke	815-672-0612
Joseph Rodriguez	815-672-3935
Dennis Vanderploeg	815-942-8131
Thomas Doran	815-942-0161
Benjamin Schrum	815-942-8552
Robert Blaine	815-634-4008
Timothy Halliday	815-634-8206
Jeff Baxter	815-634-2975
Jack Querciagrossa	815-433-2291
Donald Lenski	815-223-2363
Charles Howard	815-476-2414
Brian Boggetto	815-744-6603
Melinda Marchetti	815-722-3602
Eugene Lorenc	815-725-9090
Andy Bebar	815-741-0288
Alvin Howard	815-723-6833
Mike Wiggins	815-937-5553
Dave Duffy	815-842-1683
Lee Rasmussen	708-553-0570



ATTACHMENT C (Cont.)  
CALL LIST D (Cont.)

Chemistry Technicians (Contact 5 at Site Emergency or General Emergency)

<u>Name</u>	<u>Home Phone</u>
Shane Marik	815-357-6345
Michael Pearson	815-795-4511
Gary Spears	815-434-1759
Nolan Hallock	815-433-3796
Kenneth Lyons	815-673-1872
Robert Rowland	815-672-2095
Robert Whitley	815-672-0756
Mark Shabala	815-673-1279
Stanley Tutoky	815-673-3661
Douglas Jerzycke	815-942-9092
Terry Anderson	815-942-4713
Donald Osterling	815-942-5364
Rudy Varju	815-722-0863

2. Record the names of the respondents on Attachment D.
3. Report completion of the call list to the Shift Engineer.
4. Call Security (extension 2496 or 2616) to arrange for breath analysis for any individual who has consumed alcohol five hours prior to reporting to the TSC.



ATTACHMENT D  
CALL LIST COMPLETION

A. Personnel Notified

Position

_____	_____
_____	_____
_____	_____
_____	_____
_____	_____
_____	_____
_____	_____
_____	_____
_____	_____
_____	_____

B. Personnel Requiring Breath Analysis

\_\_\_\_\_  
\_\_\_\_\_

C. Report completion of call list to Shift Engineer. Extension 2204.

D. Call Security (Extension 2496 or 2616) to arrange for breath analysis for any individual who has consumed alcohol five hours prior to reporting to the TSC.

ZWLZP