

PHILADELPHIA ELECTRIC COMPANY

NUCLEAR GROUP HEADQUARTERS

955-65 CHESTERBROOK BLVD.

WAYNE, PA 19087-5691

(215) 640-6000

March 23, 1990

Docket Nos. 50-352  
50-353

License Nos. NPP-39  
NPP-85

U.S. Nuclear Regulatory Commission  
ATTN: Document Control Desk  
Washington, D. C. 20555

SUBJECT: Limerick Generating Station, Units 1 and 2  
Technical Specifications Change Request

Dear Sir:

Philadelphia Electric Company hereby submits Technical Specifications Change Request No. 89-14, in accordance with 10 CFR 50.90, requesting an amendment to the Technical Specifications (TS) (Appendix A) of Operating License Nos. NPP-39 and NPP-85. Information supporting this Change Request is contained in Attachment 1 to this letter. The proposed replacement pages are contained in Attachment 2. All proposed changes are indicated in the text by revision bars in the margin.

This submittal requests changes to TS Section 3/4.0 and associated Bases to remove the 3.25 limit on extending surveillance intervals. This TS change request is in accordance with the guidance provided in NRC Generic Letter 89-14, "Line-Item Improvements in Technical Specifications - Removal of the 3.25 Limit on Extending Surveillance Intervals," dated August 21, 1989.

9004100423 900323  
FDR ADOCK 05000352  
FDC

A001  
41

If you have any questions regarding this matter, please contact us.

Very truly yours,

*G. A. Hunger, Jr.*

G. A. Hunger, Jr.  
Director  
Licensing Section  
Nuclear Services Department

Attachments

cc: W. T. Russell, Administrator, Region I, USNRC  
T. J. Kenny, USNRC Senior Resident Inspector, LGS  
T. M. Gerusky, Director, PA Bureau of Radiological Protection

TECHNICAL SPECIFICATIONS CHANGE REQUEST NO. 89-14


COMMONWEALTH OF PENNSYLVANIA :

: SS.


COUNTY OF CHESTER :

D. R. Helwig, being first duly sworn, deposes and says:

That he is Vice President of Philadelphia Electric Company; the Applicant herein; that he has read the foregoing Application for Amendment of Facility Operating Licenses to remove the 3.25 limit on extending surveillance intervals, and knows the contents thereof; and that the statements and matters set forth therein are true and correct to the best of his knowledge, information and belief.

  
Vice President

Subscribed and sworn to  
before me this 23<sup>rd</sup> day  
of March 1990.

  
Notary Public

