



**Public Service®**

**Public Service  
Company of Colorado**  
P.O. Box 840  
Denver CO 80201-0840

A. Clegg Crawford  
Vice President  
Nuclear Operations

April 2, 1990  
Fort St. Vrain  
Unit No. 1  
P-90096

U. S. Nuclear Regulatory Commission  
ATTN: Document Control Desk  
Washington, D. C. 20555

Docket No. 50-267

SUBJECT: FPOR-12, Issue 4

REFERENCE: NRC Letter Heitner to Williams, dated May 18, 1989  
(G-89185)

Gentlemen:

Enclosed is one signed original and ten additional copies of the Fire Protection Operability Requirement (FPOR) 12, Issue 4, and the revised Table of Contents (TOC), Issue 9. The TOC and FPOR are contained in Section FP.6.1 of the Fort St. Vrain (FSV) Fire Protection Program Plan as approved in the referenced letter. FPOR-12 is being submitted under the requirements of 10CFR50.71(e).

The attachment to this letter is a summary of the changes to the FPOR. A 10CFR50.59 safety evaluation was performed on this issue of FPOR-12. The evaluation determined that the revisions were not safety related, were not safety significant and did not involve or create an unreviewed safety question. The revisions do not require changes to the FSV Technical Specifications.

If you have any questions or comments, please contact Mr. M. H. Holmes at (303) 480-6960.

Very truly yours,

A. Clegg Crawford  
Vice President  
Nuclear Operations

ACC/DLF/km

9004110007 900402  
FDR ADUCK 05000267  
F PDC

A006  
11

P-90096  
Page 2  
April 2, 1990

Attachment

Enclosures

cc: Regional Administrator, Region IV  
ATTN: Mr. T. F. Westerman, Chief  
Projects Section B  
(with one copy of Enclosures)

Mr. R. E. Farrell  
Senior Resident Inspector  
Fort St. Vrain  
(Enclosures previously delivered)

UNITED STATES OF AMERICA  
NUCLEAR REGULATORY COMMISSION

In the Matter of the Fire Protection Program)  
Plan of )  
Public Service Company of Colorado ) Docket No. 50-267  
Fort St. Vrain Unit No. 1 )

AFFIDAVIT

A. Clegg Crawford being first duly sworn, deposes and says: That he is Vice President, Nuclear Operations, of Public Service Company of Colorado, the Licensee herein, that he has read the information presented in the attached letter and knows the contents thereof, and that the statements and matters set forth therein are true and correct to the best of his knowledge, information and belief.

A. Clegg Crawford  
A. Clegg Crawford  
Vice President  
Nuclear Operations

STATE OF COLORADO )  
COUNTY OF DENVER )

Subscribe and sworn to before me, a Notary Public on this  
30th day of March, 1990.

Delores Romero  
Notary Public

My commission expires January 6, 1993.

ATTACHMENT TO

P-90096

SUMMARY OF CHANGES

SUMMARY OF CHANGES  
FPOR-12

The NOTE contained in the ACTION Section regarding the Control Room annunciator and Table FPOR-12-2 has been deleted. Also, appropriate revision was made to the BASIS and Table FPOR-12-2 has been deleted.

A spelling error in the first sentence of the BASIS has been corrected.

TABLE FPOR-12-1 is extensively changed to correct plant locations, clarify wording, create a consistent format for the Table, and add new detectors as a result of design modifications. Also, the oil mist detector and control unit for zone number 16 have been removed from the Table since the Hydraulic Oil System (System 91) has been removed from operational service.