

Table 4.1-1 (Cont.)

Channel Description	Check	Test	Calibrate	Remarks
47. RCS Subcooling Margin Monitor	D	NA	R	
48. Electromatic Relief Valve Flow Monitor	D	NA	R	
49. Electromatic Relief Block Valve Position Indicator	D	NA	R	
50. Pressurizer Safety Valve Flow Monitor	D	NA	R	
51. Pressurizer Water Level Indicator	D	NA	R	
52. Control Room Chlorine Detector D		M	R	
53. EFW Initiation				
a. Manual	NA	M	NA	
b. SG Low Level, SGA or B	S	M	R	
c. Low Pressure SGS or B	S	M	R	
d. Loss of both MFW Pumps and PWR > 10%	S	M	R	

Amendment No. 28, 29, 30, 31, 72b1

9004180159 900330  
 PWR ADNUCK 05000313  
 PDC