

REFUELING OPERATIONS

LOW WATER LEVEL

LIMITING CONDITION FOR OPERATION

3.9.8.2 Two decay heat removal (DHR) loops shall be OPERABLE.*

APPLICABILITY: MODE 6 when the water level above the top of the irradiated fuel assemblies seated within the reactor pressure vessel is less than 23 feet.

ACTION

- a. With less than the two required DHR loops OPERABLE, initiate corrective action to return the required loops to OPERABLE status.
- b. The provisions of Specification 3.0.3 are not applicable.

SURVEILLANCE REQUIREMENTS

4.9.8.2 No additional surveillance requirements other than those required by Specification 4.0.5.

*The normal or emergency power source may be inoperable for each DHR loop.

9004190104 900326
PDR ADOCK 05000302
PDC