

CATAWBA NUCLEAR STATION
MONTHLY OPERATING STATUS REPORT

February 1990

1. Personnel Exposure

For the month of February, 40 individual(s) exceeded 10 percent of their allowable annual radiation dose limit with the highest dose being 1.905 rem, which represents approximately 15.9% of that person's allowable annual limit.

2. The total station liquid release for February has been compared with the Technical Specifications maximum annual dose commitment and was less than 10 percent of this limit.

The total station gaseous release for February has been compared with the Technical Specifications maximum annual dose commitment and was less than 10 percent of this limit.

9004190246 900413
PDR ADOCK 05000413
R PDC