

ATTACHMENT 2

PEACH BOTTOM ATOMIC POWER STATION
UNIT 3

Docket No. 50-278

License No. DPR-56

TECHNICAL SPECIFICATION CHANGES

234a

9004230453 900412
FDR ADDOCK 05000278
P PIC

LIMITING CONDITIONS FOR OPERATION3.11.D. Shock Suppressors
(Snubbers) on Safety Related
Systems

3.11.D.1 During all modes of operation all snubbers on safety-related systems shall be operable except as noted in 3.11.D.2 and 3.11.D.3 below. Snubbers on non-safety related systems are excluded from this requirement if their failure or failure of the system on which installed has no adverse effect on a safety-related system.

3.11.D.2 During operation in the cold shutdown or refueling modes, snubbers located on systems required to be operable shall be operable except as noted in 3.11.D.3.

3.11.D.3 With one or more snubbers inoperable under the requirements of 3.11.D.1, within 72 hours, replace or restore the inoperable snubber to the operable status and perform an engineering evaluation per specification 4.11.D.6. If these requirements cannot be met, declare the supported system inoperable and follow the applicable Limiting Condition for Operation for that System.

SURVEILLANCE REQUIREMENTS4.11.D. Shock Suppressors
(Snubbers) on Safety Related
Systems

4.11.D.1

Snubbers required to be operable under the provisions of 3.11.D.1 shall be demonstrated OPERABLE by performance of the following augmented inservice inspection program and the requirements of Specification 4.6.G.

4.11.D.2

Snubbers required to be operable under the provisions of 3.11.D.1 shall be visually inspected according to the following schedule.

No. of Snubbers Found Inoperable During Inspection Period	Next Visual Inspection Period*
0	18 mo. + 25%
1	12 mo. + 25%
2	6 mo. + 25%
3,4	4 mo. + 25%
5,6,7	2 mo. + 25%
8 or more	1 mo. + 25%

The required inspection interval shall not be lengthened more than one step at a time. The provisions for extending surveillance frequency included in Section 1.0 Definitions do not apply. Snubbers may be categorized in two groups, "accessible" or "inaccessible", based on their accessibility for inspection during reactor operation. These two groups may be inspected independently according to the above schedule.

*Those surveillances on inaccessible snubbers which must be performed on or before May 26, 1990 and are required by TS 4.11.D.2 may be delayed for a period not to exceed December 31, 1990.