

UNITED STATES OF AMERICA
NUCLEAR REGULATORY COMMISSION

In the Matter of)
)
Duquesne Light Company)
Beaver Valley Power Station)

UNIT NO. 2
Docket No. 50-412
License No. NPF-73

APPLICATION FOR AMENDMENT
TO OPERATING LICENSE

Pursuant to Section 50.90 of the regulations of the U. S. Nuclear Regulatory Commission, Duquesne Light Company hereby requests that the Technical Specifications be amended to support removal of the existing Reactor Coolant System hot leg and cold leg Resistance Temperature Detector (RTD) bypass system and replace it with fast response thermowell mounted RTD's installed in the reactor coolant loop piping.

The proposed technical specification change is set forth in Attachment A to this Application. A Safety Analysis and No Significant Hazard Evaluation is set forth in Attachment B. Based on the guidance provided by the Commission, the proposed changes have been determined to involve no significant hazards consideration in accordance with 10 CFR 50.92.

WHEREFORE, Applicant respectfully requests that Appendix A to these Operating Licenses be amended in the form attached hereto as Attachment A.

Duquesne Light Company

By


J. D. Sieber

J. D. Sieber
Vice President, Nuclear

Subscribed and sworn to before me

on this *16th* day of *April*, *1990*

Tracey A. Baczek



Member, Pennsylvania Association of Notaries

9004240468 900416
PDR ADOCK 05000412
PDC