

ATTACHMENT 2

PEACH BOTTOM ATOMIC POWER STATION
UNITS 2 AND 3

Docket Nos. 50-277
50-278

License Nos. DPR-44
DPR-56

TECHNICAL SPECIFICATION CHANGES

List of Attached Pages

<u>Unit 2</u>	<u>Unit 3</u>
iva	iv
vii	vii
243	243
244	244
245	245
245a	245a
246	246
252	252
252a	252a

LIST OF FIGURES

<u>Figure</u>	<u>Title</u>	<u>Page</u>
3.5.1.I	MAPLHGR vs. Planar Average Exposure Unit 2, P8X8R Fuel, Type P8DRB284H, 80 mil & 100 mil channel & 120 mil channels	142h
3.5.1.J	MAPLHGR vs. Planar Average Exposure Unit 2, P8X8R and BP8X8R Fuel, Type P8DRB299 and BP8DRB299, 100 mil channels	142i
3.5.1.K	MAPLHGR vs. Planar Average Exposure Unit 2, P8X8R Fuel (Generic)	142j
3.5.1.L	MAPLHGR vs. Planar Average Exposure Unit 2, BP8X8R Fuel, Type BP8DRB299H	142k
3.5.1.M	MAPLHGR vs. Planar Average Exposure Unit 2, GE8X8EB Fuel, Type BD319A	142l
3.5.1.N	MAPLHGR vs. Planar Average Exposure Unit 2, GE8X8EB, Type BD321A	142m
3.5.1.O	MAPLHGR vs. Planar Average Exposure Unit 2, GE8X8EB, Type LTA310	142n
3.6.1	Minimum Temperature for Pressure Tests such as required by Section XI	164
3.6.2	Minimum Temperature for Mechanical Heatup or Cooldown following Nuclear Shutdown	164a
3.6.3	Minimum Temperature for Core Operation (Criticality)	164b
3.6.4	Deleted	164c
3.6.5	Thermal Power and Core Flow Limits	164d
3.8.1	Site Boundary and Effluent Release Points	216e
6.2-1	Deleted	
6.2-2	Deleted	

PBAPS

LIST OF TABLES

<u>Table</u>	<u>Title</u>	<u>Page</u>
4.8.3.c	Maximum Values for Minimum Detectable Levels of Activity	216d-6
3.14.C.1	Fire Detectors	240m
3.15	Seismic Monitoring Instrumentation	240u
3.15	Seismic Monitoring Instrumentation Surveillance Requirements	240v
6.2.1	Shift Crew Composition-Minimum Requirements	245

Table 6.2.1

Shift Crew Composition - Minimum Requirements

One or Both Units Operating*:	1 Shift Manager (SRO)
	1 Shift Supervisor (SRO)
	3 Reactor Operators (RO)
	5 Operators
Both Units not Operating*	1 Shift Technical Advisor
	1 Shift Manager or Shift Supervisor (SRO)
	2 Reactor Operators (RO)
	5 Operators

SRO - NRC licensed senior reactor operator

RO - NRC licensed reactor operator

* For the purpose of this table, a unit is considered not to be operating when it is in a Cold Condition with the reactor mode switch in shutdown or refuel.

PBAPS
LIST OF FIGURES

<u>Figure</u>	<u>Title</u>	<u>Page</u>
1.1-1	APRM Flow Bias Scram Relationship To Normal Operating Conditions	16
4.1.1	Instrument Test Interval Determination Curves	55
4.2.2	Probability of System Unavailability vs. Test Interval	98
3.3.1	SRM Count Rate vs. Signal-to-Noise Ratio	103a
3.4.1	DELETED	122
3.4.2	DELETED	123
3.5.K.1	MCPR Operating Limit vs. Tau, BP/P8X8R, LTA, GE8X8EB Fuel, Standard Operating Conditions	142
3.5.K.2	MCPR Operating Limit vs. Tau, BP/P8X8R, LTA, GE8X8EB Fuel, Increased Core Flow	142a
3.5.1.A	DELETED	
3.5.1.B	DELETED	
3.5.1.C	DELETED	
3.5.1.D	DELETED	
3.5.1.E	Kf Factor vs. Core Flow	142d
3.5.1.F	MAPLHGR vs. Planar Average Exposure, Unit 3, GE8X8EB Fuel (Type BD 319A)	142e
3.5.1.G	MAPLHGR vs. Planar Average Exposure, Unit 3, GE8X8EB Fuel (Type BD321A)	142f
3.5.1.H	MAPLHGR vs. Planar Average Exposure, Unit 3 P8X8R Fuel (P8DRB284H)	142g
3.5.1.I	MAPLHGR vs. Planar Average Exposure, Unit 3 P8X8R and BP8X8R Fuel (P8DRB299 and BP8DRB299)	142h
3.5.1.J	MAPLHGR vs. Planar Average Exposure, Unit 3 BP8X8R Fuel (BP8DRB299H)	142i
3.5.1.K	MAPLHGR vs. Planar Average Exposure, Unit 3 P8X8Q LTA (P8DQB326)	142j
3.6.1	Minimum Temperature for Pressure Tests such as required by Section IX	164
3.6.2	Minimum Temperature for Mechanical Heatup or Cooldown following Nuclear Shutdown	164a
3.6.3	Minimum Temperature for Core Operation (Criticality)	164b
3.6.4	Transition Temperature Shift vs. Fluence	164c
3.6.5	Thermal Power Limits of Specifications	164d
3.8.1	3.6.F.3, 3.6.F.4, 3.6.F.5, 3.6.F.6 and 3.6.F.7 Site Boundary and Effluent Release Points	216e
6.2-1	DELETED	
6.2-2	DELETED	

PBAPS

LIST OF TABLES

<u>Table</u>	<u>Title</u>	<u>Page</u>
4.8.3.c	Maximum Values for Minimum Detectable Levels of Activity	216d-6
3.14.C.1	Fire Detectors	240m
3.15	Seismic Monitoring Instrumentation	240u
4.15	Seismic Monitoring Instrumentation Surveillance Requirements	240v
6.2.1	Shift Crew Composition-Minimum Requirements	245

Table 6.2.1

Shift Crew Composition - Minimum Requirements

One or Both Units Operating*:	1 Shift Manager (SRO)
	1 Shift Supervisor (SRO)
	3 Reactor Operators (RO)
	5 Operators
	1 Shift Technical Advisor
Both Units not Operating*	1 Shift Manager or Shift Supervisor (SRO)
	2 Reactor Operators (RO)
	5 Operators

SRO - NRC licensed senior reactor operator

RO - NRC licensed reactor operator

* For the purpose of this table, a unit is considered not to be operating when it is in a Cold Condition with the reactor mode switch in shutdown or refuel.