

Duke Power Company
Box 33198
Durham, N.C. 28242

Hal B. Tucker
Vice President
Nuclear Production
(704)373-4531



DUKE POWER

April 23, 1990

U. S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, DC 20555

Subject: Catawba Nuclear Station, Units 1 and 2
Docket Nos. 50-413 and 50-414
Proposed Technical Specification Amendment
Technical Specification 4.7.7

Gentlemen:

Please find attached a proposed amendment to Technical Specification (TS) 4.7.7. This change will require that the laboratory test of the carbon samples from the Auxiliary Building Filtered Exhaust System be tested at 95% relative humidity and 30°C, for a methyl iodide penetration of 0.71%.

Attachment I contains the marked up TS and Bases pages. Attachment II contains a discussion, Technical Justification, No Significant Hazards Analysis, and an Environmental Impact Statement.

Pursuant to 10 CFR 50.91(b)(1) the appropriate South Carolina State Official is being provided a copy of this amendment request.

Very truly yours,

A handwritten signature in cursive script, reading 'Hal B. Tucker'.

H. B. Tucker

MHH27/td

9005010071 900423
PDR ADDCK 05000413
P PDC

A001
11

U. S. Nuclear Regulatory Commission
April 23, 1990
Page 2

cc: Mr. S. D. Ebner
Regional Administrator
U. S. Nuclear Regulatory Commission
Region II
101 Marietta Street, NW, Suite 2900
Atlanta, GA 30323

Mr. Heyward Shealy, Chief
Bureau of Radiological Health
South Carolina Department of Health and
Environmental Control
2600 Bull Street
Columbia, SC 29201

American Nuclear Insurers
c/o Dottie Sherman, ANI Library
The Exchange, Suite 245
270 Farmington Avenue
Farmington, CT 06032

M & M Nuclear Consultants
1221 Avenue of the Americas
New York, New York 10020


INPO Records Center
Suite 1500
1100 Circle 75 Parkway
Atlanta, GA 30339

Mr. W. T. Orders
NRC Resident Inspector
Catawba Nuclear Station

Dr. K. N. Jabbour
Office of Nuclear Regulation
U. S. Nuclear Regulatory Commission
One White Flint North
Mail Stop 14H25
Washington, DC 20555

U. S. Nuclear Regulatory Commission
April 23, 1990
Page 3

Hal B. Tucker, being duly sworn, states that he is Vice President of Duke Power Company; that he is authorized on the part of said Company to sign and file with the Nuclear Regulatory Commission this revision to the Catawba Nuclear Station Technical Specifications, Appendix A to License Nos. NPF-35 and NPF-52; and that all statements and matters set forth therein are true and correct to the best of his knowledge.



Hal B. Tucker, Vice President

Subscribed and sworn to before me this 23rd day of April, 1990.


Notary Public

My Commission Expires:

May 7, 1994



ATTACHMENT I