

Nuclear

GPU Nuclear Corporation

Post Office Box 388
Route 9 South
Forked River, New Jersey 08731-0388
609 971-4000
Writer's Direct Dial Number:

April 25, 1990

U.S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, D.C. 20555

Dear Sir:

Subject: Oyster Creek Nuclear Generating Station
Docket No. 50-219
Response to Bulletin 89-02

The purpose of this letter is to confirm, as requested by the subject Bulletin, that the Oyster Creek Nuclear Generating Station does not utilize Anchor Darling Model S350W swing check valves with type 410SS bolts in any safety related application.

In addition, drawings for other manufacturer's check valves installed at Oyster Creek have been reviewed and it has been determined that Crane and Ohio Injector have designs similar to Model S350W, but do not use 410SS internal bolting.

Bulletin 89-02 does not apply to Oyster Creek because Oyster Creek does not have any Anchor Darling Model S350W check valves in safety related applications. Check valves of similar design used at Oyster Creek do not have 410SS internal bolting.

If further information is required, please contact Brenda DeMerchant, OC Licensing Engineer at (609) 971-4642.

Very truly yours,

E.E. Fitzpatrick

E.E. Fitzpatrick
Vice President and Director
Oyster Creek

EEF/BDeM/jc

c: Mr. Thomas Martin, Administrator
Region 1
U.S. Nuclear Regulatory Commission
475 Allendale Road
King of Prussia, PA 19406

NRC Resident Inspector
Oyster Creek Nuclear Generating Station

Mr. Alexander Dromerick
U.S. Nuclear Regulatory Commission
Mail Station P1-137
Washington, DC 20555

Sworn to and subscribed before me this

25th day of April, 1990

Judith M. Crowe

JUDITH M. CROWE
Notary Public of New Jersey
My Commission Expires 1-25-95