

Georgia Power Company
333 Piedmont Avenue
Atlanta, Georgia 30308
Telephone 404 526-3195

Mailing Address:
40 Inverness Center Parkway
Post Office Box 1295
Birmingham, Alabama 35201
Telephone 205 868-5581

the southern electric system

W. G. Hairston, III
Senior Vice President
Nuclear Operations

April 26, 1990

MSV-00198
#620

Docket No. 50-424

U. S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, D.C. 20555

VOGTLE ELECTRIC GENERATING PLANT - UNIT 1
REVISION 4 TO INSERVICE INSPECTION PROGRAM

Gentlemen:

In accordance with Georgia Power Company (GPC) letter MSV-00169 dated March 27, 1990, enclosed is Revision 4 to the Vogtle Electric Generating Plant, Unit 1 (VEGP-1) Inservice Inspection (ISI) Program, ISI-P-005. The revision is being submitted for NRC review and approval in accordance with Technical Specification 4.0.5 concerning surveillance requirements. The enclosed documents supersede portions of the original ISI program previously submitted. A summary of the changes resulting from Revision 4 is also enclosed. Ten copies of this submittal are provided herein for your convenience.

Revision 4 to the VEGP-1 ISI Program includes the withdrawal of Relief Requests RR-45, 47, 48 and 54 which were discussed in GPC letter MSV-00169. In addition to the program changes resulting from the withdrawal of the aforementioned relief requests, Relief Requests RR-12 and RR-32 have been revised. Relief Request RR-12 has been revised to delete a reference to Relief Request RR-13 which was withdrawn by Revision 1 to the VEGP-1 ISI Program and to add a statement specifically indicating why relief was being requested. Relief Request RR-32 has been revised to include the surface examination of the reinforcing plate-to-vessel welds in the Residual Heat Removal (RHR) System heat exchangers, elaborate upon the requested relief, and to better graphically depict the VEGP-1 RHR heat exchangers nozzle and vessel shell configuration. The resulting change in Relief Request RR-32 makes that relief request similar in content to Relief Request RR-32 for Unit 2 at Vogtle. Finally, Relief Requests RR-55 and RR-56 have been added to the ISI program although the subject relief requests are intentionally being left blank. This is being done for administrative purposes in order that the relief request numbering sequence and relief request content will correspond between the two Vogtle units, e.g., Relief Requests RR-11 are similar for both Vogtle units.

9005020063 900426
PDR ADOCK 05000424
Q PDC


A047
11

U. S. Nuclear Regulatory Commission
MSV-00198
Page 2
April 26, 1990

The NRC is requested to review and grant approval of the enclosed ISI program changes in accordance with 10 CFR 50.55a (g)(6)(i). Relief requested by the enclosed changes does not affect public health and safety. Approval of the enclosed ISI program revision is requested by November 1, 1990.

Should there be any questions in this regard, please contact this office.

Sincerely,


W. G. Hairston, III

WGHIII/JAE/gb

Enclosure: Revision 4 to VEGP-1 ISI Program, ISI-P-006

xc: Georgia Power Company
Mr. C. K. McCoy
Mr. G. Bockhold, Jr.
Mr. R. M. Odom
Mr. P. D. Rushton
Mr. L. A. Ward
NORMS

U. S. Nuclear Regulatory Commission
Mr. R. F. Aiello, Senior Resident Inspector, Vogtle
Mr. S. D. Ebnetter, Regional Administrator
Mr. T. A. Reed, Licensing Project Manager, NRR