

ILLINOIS POWER

CLINTON POWER STATION, P.O. BOX 678, CLINTON, ILLINOIS 61727

U-601654
L30-90(4-26)-LP
8G.120

J. STEPHEN PERRY, Vice President
(217) 935-6226

JSP-0325-90
April 26, 1990

Docket No. 50-461

Nuclear Regulatory Commission
Document Control Desk
Washington, D.C. 20555


Subject: Clinton Power Station
Response to Generic Letter 89-19

Dear Sir:

This letter is in response to Generic Letter (GL) 89-19, "Request for Action Related to Resolution of Unresolved Safety Issue A-47, 'Safety Implication of Control Systems in LWR Nuclear Power Plants.'" Illinois Power Company (IP) is providing this response to formally endorse the Boiling Water Reactor Owners Group's (BWROG) letter to the Nuclear Regulatory Commission dated April 2, 1990. The BWROG report presents the results of a study of automatic overfill protection systems currently utilized by Boiling Water Reactors (BWR). The report concludes that the BWRs addressed by the report provide adequate and reliable automatic overfill protection consistent with the NRC requirements for closure of unresolved Safety Issue A-47. IP's Clinton Power Station was one of the Nuclear Power Plants participating in the BWROG evaluation of GL 89-19.

I hereby affirm that the information in this letter is correct to the best of my knowledge.

Sincerely yours,


J. S. Perry
Vice President

REL/alh

cc: Regional Administrator, Region III, USNRC
NRC Clinton Licensing Project Manager
NRC Resident Office
Illinois Department of Nuclear Safety

9005030351 900426
PDR ADOCK 05000461
P FDC

A001
110