

OPERATING DATA REPORT

DOCKET NO. 50-341

COMPLETED BY P. M. Anthony

DATE May 15, 1990

TELEPHONE (313) 586-1617

OPERATING STATUS

1. UNIT NAME: Ferri 2 Notes: |
2. REPORTING PERIOD: March, 1990 |
3. LICENSED THERMAL POWER (Mwt): 3293 |
4. NAMEPLATE RATING (GROSS MWe): 1154 |
5. DESIGN ELECT RATING (Net MWe): 1067 |
6. MAX DEPENDABLE CAP (GROSS MWe): 1154 |
7. MAX DEPENDABLE CAP (Net MWe): 1067 |
8. IF CHANGES OCCUR IN CAPACITY RATINGS (ITEMS NUMBER 3 THROUGH 7) SINCE LAST REPORT, GIVE REASONS: Lines 5 through 7 revised based on ECAR testing.
9. POWER LEVEL TO WHICH RESTRICTED, IF ANY (MWe Net): None
10. REASONS FOR RESTRICTION, IF ANY: None

	THIS MONTH	YR TO DATE	CUMULATIVE
11. HRS IN REPORTING PERIOD	<u>744</u>	<u>2160</u>	<u>19,166</u>
12. HRS REACTOR WAS CRITICAL	<u>744</u>	<u>2160</u>	<u>13,256.9</u>
13. REACTOR RESERVE SHUTDOWN HRS	<u>0</u>	<u>0</u>	<u>0</u>
14. HOURS GENERATOR ON-LINE	<u>744</u>	<u>2160</u>	<u>12,456.8</u>
15. UNIT RESERVE SHUTDOWN HOURS	<u>0</u>	<u>0</u>	<u>0</u>
16. GROSS THERMAL ENERGY GEN (MWH)	<u>2,413,032</u>	<u>6,895,800</u>	<u>36,257,762</u>
17. GROSS ELECT ENERGY GEN (MWH)	<u>815,670</u>	<u>2,330,000</u>	<u>12,074,357</u>
18. NET ELECT ENERGY GEN (MWH)	<u>782,916</u>	<u>2,235,906</u>	<u>11,548,757</u>
19. UNIT SERVICE FACTOR	<u>100</u>	<u>100</u>	<u>65.0</u>
20. UNIT AVAILABILITY FACTOR	<u>100</u>	<u>100</u>	<u>65.0</u>
21. UNIT CAP FACTOR (USING MDC NET)	<u>98.6</u>	<u>97.0</u>	<u>55.3</u>
22. UNIT CAP FACTOR (USING DER NET)	<u>98.6</u>	<u>97.0</u>	<u>55.3</u>
23. UNIT FORCED OUTAGE RATE	<u>0</u>	<u>0</u>	<u>15.1</u>

24. SHUTDOWNS SCHEDULED OVER NEXT 6 MONTHS (TYPE, DATE, DURATION OF EACH)
None.

25. IF SHUT DOWN AT END OF REPORT PERIOD, ESTIMATED DATE OF STARTUP: N/A

26. UNITS IN TEST STATUS (PRIOR TO COMMERCIAL OPERATION):

	FORECAST	ACHIEVED
INITIAL CRITICALITY	<u>N/A</u>	<u>N/A</u>
INITIAL ELECTRICITY	<u>N/A</u>	<u>N/A</u>
COMMERCIAL OPERATION	<u>N/A</u>	<u>N/A</u>

9005210272 900515
PDR ADOCK 05000341
R PDC