



NIAGARA MOHAWK POWER CORPORATION/NINE MILE POINT, P.O. BOX 63, LYCOMING, NY 13093/TELEPHONE (315) 349-2882

B. Ralph Sylvia
Executive Vice President
Nuclear

February 12, 1993
NMP2L 1369

U. S. Nuclear Regulatory Commission
Attention: Document Control Desk
Washington, D. C. 20555


Re: Nine Mile Point Unit 2
Docket No. 50-410
NPF-69

Gentlemen:

Niagara Mohawk Power Corporation hereby transmits an Application for Amendment to Nine Mile Point Unit 2 Operating License NPF-69. Also enclosed are the proposed changes to the Technical Specifications set forth in Appendix A of the above referenced license. Supporting information and analysis demonstrating that the proposed changes do not involve a significant hazards consideration pursuant to 10 CFR 50.92 are included in Attachment B.

The proposed changes are to Technical Specifications Table 1.2, "Operational Conditions," and Section 3/4.9.1, "Reactor Mode Switch." This amendment will allow a single control rod to be withdrawn when the plant is in the Hot Shutdown or Cold Shutdown Condition provided the one-rod-out interlock is OPERABLE and the Mode Switch is in the Refuel position. Currently, post-maintenance and surveillance testing on control rod drives is a critical path activity during plant startup after a refueling outage. These proposed changes would permit the performance of control rod drive testing during cold shutdown, thereby shortening the critical path schedule. These proposed changes have no safety or environmental significance.

Pursuant to 10CFR50.91(b)(1), Niagara Mohawk has provided a copy of this license amendment request and the associated analyses regarding no significant hazards consideration to the appropriate state representative.

Very truly yours,

B. Ralph Sylvia
Exec. Vice President-Nuclear

RW/sck
002951LL
Attachments

xc: Regional Administrator, Region I
Mr. W. L. Schmidt, Senior Resident Inspector
Mr. R. A. Capra, Director, Project Directorate I-1, NRR
Mr. J. E. Menning, Project Manager, NRR
Ms. Donna Ross
Division of Policy Analysis
New York State Energy Office
Agency Building 2
Empire State Plaza
Albany, NY 12223
Records Management

240023

9302250152 930212
PDR ADOCK 05000410
P PDR

Foot
11/1