



**CENTERIOR
ENERGY**

Donald C. Shelton
Vice President - Nuclear
Davis-Besse

300 Madison Avenue
Toledo, OH 43652-0001
(419) 249-2300

Docket Number 50-346

License Number NPF-3

Serial Number 2025

February 17, 1993

United States Nuclear Regulatory Commission
Document Control Desk
Washington, D. C. 20555

Subject: License Amendment Request to Revise Technical Specifications
Safety Features Actuation System and Steam and Feedwater
Rupture Control System Instrumentation Setpoints

Gentlemen:

Enclosed is an application for an amendment to the Davis-Besse Nuclear Power Station (DBNPS), Unit 1, Operating License Number NPF-3, Appendix A Technical Specifications (TS). The proposed changes involve TS 3/4.3.2.1, "Safety Features Actuation System Instrumentation," and TS 3/4.3.2.2, "Steam and Feedwater Rupture Control System Instrumentation."

The proposed TS changes, which are a result of part of the Design Bases Reconstitution (DBR) Program at the DBNPS, revise some of the trip setpoints and the allowable values for the Safety Features Actuation System (SFAS) and the Steam and Feedwater Rupture Control System (SFRCS) to incorporate revised instrument string error allowances based on the methodology of the Instrument Society of America Standard, ISA S67.04-1982, Setpoints for Nuclear Safety Related Instrumentation. The instrument string errors were reanalyzed in order to provide consistency in the methodology used to determine the SFAS and SFRCS TS values. Additionally, an increase in the containment high radiation trip is being proposed to provide margin to accommodate normal changes in background radiation.

Toledo Edison requests timely review of this amendment request by the Nuclear Regulatory Commission, with implementation to be completed prior to startup from the next refueling outage after approval of the license amendment. This will permit the revised setpoints to be implemented during a refueling outage.

250008

Operating Companies:
Cleveland Electric Illuminating
Toledo Edison


9302260144 920217
PDR ADDCK 05000346
PDR

Food
1/1

Docket Number 50-346
License Number NPF-3
Serial Number 2025
Page 2

If you have any questions regarding this amendment request, please contact Mr. Robert W. Schrauder, Manager - Nuclear Licensing, at (419) 249-2366.

Very truly yours,



PWS/dlc

enclosure

cc: A. B. Davis, Regional Administrator, NRC Region III
J. B. Hopkins, NRC/NRR DB-1 Senior Project Manager
S. Stasek, NRC Region III, DB-1 Senior Resident Inspector
J. R. Williams, Chief of Staff, Ohio Emergency Management
Agency, State of Ohio (NRC Liaison)
Utility Radiological Safety Board