



South Carolina Electric & Gas Company  
P.O. Box 88  
Jenkinsville, SC 29065  
(803) 345-4040

John L. Skolds  
Vice President  
Nuclear Operations

February 23, 1993  
Refer to: RC-93-0048

Document Control Desk  
U. S. Nuclear Regulatory Commission  
Washington, DC 20555

Gentlemen:

Subject: VIRGIL C. SUMMER NUCLEAR STATION (VCSNS)  
DOCKET NO. 50/395  
OPERATING LICENSE NO. NPF-12  
RESPONSE TO NRC BULLETIN 92-01  
SPECIAL REPORT 92-005 (ONO 920050)  
RESPONSE TO NRC BULLETIN 92-01 SUPPLEMENT 1  
SPECIAL REPORT 92-005 SUPPLEMENT 1

During a review of the subject correspondence, submitted on 20 July 1992 and 15 September 1992 respectively, a discrepancy was noted in Table B of the attachment.

Enclosed are corrected Table B attachments for your file.

Should there be any questions, please contact Mr. R. J. Bouknight at (803) 345-4085.

Very truly yours,

John L. Skolds

RJB:smd  
Enclosure

c: O. W. Dixon  
R. R. Mahan  
R. J. White  
General Managers  
G. F. Wunder  
S. R. Hunt  
NRC Resident Inspector  
J. B. Knotts Jr.  
Marsh & McLennan  
Document Control Desk  
INPO Records Center  
NSRC  
RTS (IE 920001)  
File (818.05 & 818.08)

9303010237 930223  
PDR ADDCK 05000395  
Q PDR

TABLE B  
 Components Supplied Through Cable Tray 3088:

Equipment Number	Name	Safety Class
XFN0038A	Battery & Charging Room Air Handling Unit "A" Supply Fan	(NNS)
XFN0039A	Battery Room Exhaust Fan "A"	(NNS)
XES2001A	Speed Switch, Component Cooling Pump "A"	(SR)
XES2001C	Speed Switch, Component Cooling Pump "C"	(SR)
XPN7200A	Control Room Evacuation Panel	(SR)
XSW0001	Reactor Trip Switchgear	(SR)
XCA0001A	Power Control Rod Groups 1A, 1C, Shutdown Group 1A	(NNS)
XCX5201	Diesel Generator "A" Control Cubicle	(SR)
XPN5503	Diesel Generator "A" Relay & Terminal Panel	(SR)
XES0006	Diesel Generator "A" Starter DC Fuel Oil Pump	(SR)
XEX4201	Diesel Generator "A" Exciter Regulator Cubicle	(SR)
XPN5248	Relay & Isolation Fuse Panel	(SR)
XBC1A	DC Distribution Bus 1A Battery Charger	(SR)
XBC1A-1B	DC Distribution Bus 1A-1B Backup Battery Charger	(SR)
XPN5259	Isolation Fuse Panel	(SR)
XSW1DA	7.2 KV Switchgear, Bus 1DA	(SR)
XSW1DA1	ESF 480 Volt Unit Substation, Bus 1DA1	(SR)
XSW1DA2	ESF 480 Volt Unit Substation, Bus 1DA2	(SR)
XPN6011	Reactor Protection Under Frequency & Under Voltage Panel 1	(SR)
XPN7105	Main Control Board Termination Cabinet	(SR)

TABLE B  
 Components Supplied Through Cable Tray 3088:

Equipment Number	Name	Safety Class
XFN0038A	Battery & Charging Room Air Handling Unit "A" Supply Fan	(NNS)
XFN0039A	Battery Room Exhaust Fan "A"	(NNS)
XES2001A	Speed Switch, Component Cooling Pump "A"	(SR)
XES2001C	Speed Switch, Component Cooling Pump "C"	(SR)
XPN7200A	Control Room Evacuation Panel	(SR)
XSW0001	Reactor Trip Switchgear	(SR)
XCA0001A	Power Control Rod Groups 1A, 1C, Shutdown Group 1A	(NNS)
XCX5201	Diesel Generator "A" Control Cubicle	(SR)
XPN5503	Diesel Generator "A" Relay & Terminal Panel	(SR)
XES0006	Diesel Generator "A" Starter DC Fuel Oil Pump	(SR)
XEX4201	Diesel Generator "A" Exciter Regulator Cubicle	(SR)
XPN5248	Relay & Isolation Fuse Panel	(SR)
XBC1A	DC Distribution Bus 1A Battery Charger	(SR)
XBC1A-1B	DC Distribution Bus 1A-1B Backup Battery Charger	(SR)
XPN5259	Isolation Fuse Panel	(SR)
XSW1DA	7.2 KV Switchgear, Bus 1DA	(SR)
XSW1DA1	ESF 480 Volt Unit Substation, Bus 1DA1	(SR)
XSW1DA2	ESF 480 Volt Unit Substation, Bus 1DA2	(SR)
XPN6011	Reactor Protection Under Frequency & Under Voltage Panel 1	(SR)
XPN7106	Main Control Board Termination Cabinet	(SR)