

ADMINISTRATIVE CONTROLS

CORE OPERATING LIMITS REPORT

4. BAW-10168P, Rev. 1, "B&W Loss-of-Coolant Accident Evaluation Model for Recirculating Steam Generator Plants," September, 1989 (B&W Proprietary).
(Methodology for Specification 3.2.2 - Heat Flux Hot Channel Factor.)
5. DPC-NE-2011P, "Duke Power Company Nuclear Design Methodology for Core Operating Limits of Westinghouse Reactors," March, 1990 (DPC Proprietary).
(Methodology for Specification 3.1.3.5 - Shutdown Rod Insertion Limits, 3.1.3.6 - Control Bank Insertion Limits, 3.2.1 - Axial Flux Difference, 3.2.2 - Heat Flux Hot Channel Factor, and 3.2.3 - Nuclear Enthalpy Rise Hot Channel Factor.)
6. DPC-NE-3001P, "Multidimensional Reactor Transients and Safety Analysis Physics Parameter Methodology," March, 1991 (DPC Proprietary).
(Methodology for Specification 3.1.1.3 - Moderator Temperature Coefficient, 3.1.3.5 - Shutdown Rod Insertion Limits, 3.1.3.6 - Control Bank Insertion Limits, 3.2.1 - Axial Flux Difference, 3.2.2 - Heat Flux Hot Channel Factor, and 3.2.3 - Nuclear Enthalpy Rise Hot Channel Factor.)
7. DPC-NE-2010P, "Duke Power Company McGuire Nuclear Station Catawba Nuclear Station Nuclear Physics Methodology for Reload Design," April, 1984 (DPC Proprietary).
(Methodology for Specification 3.1.1.3 - Moderator Temperature Coefficient.)
8. DPC-NE-3002, "FSAR Chapter 15 System Transient Analysis Methodology," August 1991.
(Methodology used in the system thermal-hydraulic analyses which determine the core operating limits)
9. DPC-NE-3000, Rev. 1, "Thermal-Hydraulic Transient Analysis Methodology," May 1989.
(Modeling used in the system thermal-hydraulic analyses)

The core operating limits shall be determined so that all applicable limits (e.g., fuel thermal-mechanical limits, core thermal-hydraulic limits, ECCS limits, nuclear limits such as shutdown margin, and transient and accident analysis limits) of the safety analysis are met.

The CORE OPERATING LIMITS REPORT, including any mid-cycle revisions or supplements thereto, shall be provided upon issuance, for each reload cycle, to the NRC Document Control Desk with copies to the Regional Administrator and Resident Inspector.

SPECIAL REPORTS

6.9.2 Special reports shall be submitted to the Regional Administrator of the NRC Regional Office within the time period specified for each report.

McGUIRE - UNITS 1 and 2

6-21a

Amendment No. ~~125~~ (Unit 1)

Amendment No. ~~110~~ (Unit 2)

10. DPC-NE-1004A, "Nuclear Design Methodology Using CASMO-3/SIMULATE-3P,"
November 1992.
(Methodology for Specification 3.1.1.3 - Moderator Temperature Coefficient.)