



Carolina Power & Light Company

Brunswick Nuclear Plant
P. O. Box 10429
Southport, N.C. 28461-0429

FEB 19 1993

FILE: B09-13510C
SERIAL: BSEP-93-0024

U.S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, D. C. 20555

BRUNSWICK STEAM ELECTRIC PLANT UNIT 1 AND 2
DOCKET NO. 50-325 & 50-324
LICENSE NO. DPR-71 & DPR-62
SPECIAL REPORT PER TECHNICAL SPECIFICATION 3.7.8 AND
PURSUANT TO TECHNICAL SPECIFICATION 6.9.2 (1-SR-93-003)


Gentlemen:

Units 1 and 2 are in Cold Shutdown for the outages started on April 21, 1992. The following summarizes fire protection Limiting Condition for Operation (LCO) A2-93-F0082:

(LCO) A2-93-F0082

At 0930 on January 19, 1993, Emergency Diesel Generator (EDG) Building fire door #121 was declared inoperable to allow a temporary power cable to be run through the door between the #3 and #4 EDG cells. This was needed to support maintenance activities on #3 EDG. Fire watches that were previously stationed were used to monitor the area until the door was restored at 1000 on February 12, 1993. This report is required as the door remained inoperable longer than the 7 days allowed by the Technical Specification.

Very truly yours,


J. M. Brown, Plant Manager Unit 2
Brunswick Nuclear Plant

cc: Mr. S. D. Ebnetter
Mr. P. D. Milano
BSEP NRC Resident Office

9303010314 930219
PDR ADDCK 05000324
S PDR

JE22 1/0