

BEFORE THE UNITED STATES
NUCLEAR REGULATORY COMMISSION

In the matter of)
NEW YORK POWER AUTHORITY) Docket No. 50-333
James A. FitzPatrick Nuclear Power Plant)

APPLICATION FOR AMENDMENT TO OPERATING LICENSE

The New York Power Authority requests an amendment to the Technical Specifications contained in Appendix A to Facility Operating License DPR-59 for the James A. FitzPatrick Nuclear Power Plant. This application is filed in accordance with Section 10 CFR 50.90 of the Nuclear Regulatory Commission's regulation.

This application for an amendment to the James A. FitzPatrick Technical Specifications proposes to revise Surveillance Requirement 4.9.G.1 and associated Bases using the guidance of Generic Letter 91-09. The Generic Letter allows a line item Technical Specification improvement by the elimination of testing for electrical protective assemblies (EPAs) during power operation. This change reduces the possibility of inadvertent reactor trips caused by testing of EPAs during power operation.

The proposed change to the Technical Specifications is Attachment I to this Application for Amendment to the Operating License. The Safety Evaluation for the proposed change is included as Attachment II.


New York Power Authority



Ralph E. Beedle
Executive Vice President
Nuclear Generation

STATE OF NEW YORK
COUNTY OF WESTCHESTER

Subscribed and sworn to before me
this 22nd day of February 1993.


Notary Public

KATHLEEN D. GALLAGHER
Notary Public, State of New York
No. 5004481
Qualified in Westchester County
Commission Expires Nov. 16, 1994