



Tennessee Valley Authority, Post Office Box 2000, Soddy-Daisy, Tennessee 37379-2000

Robert A. Fenech  
Vice President, Sequoyah Nuclear Plant

March 1, 1993

TVA-SQN-TS-93-03

10 CFR 50.90

U.S. Nuclear Regulatory Commission  
ATTN: Document Control Desk  
Washington, D.C. 20555

Gentlemen:

In the Matter of  
Tennessee Valley Authority

)  
)

Docket Nos. 50-327  
50-328

SEQUOYAH NUCLEAR PLANT (SQN) - TECHNICAL SPECIFICATION (TS) CHANGE 93-03,  
"DIESEL GENERATOR (D/G) VOLTAGE OVERSHOOT LIMIT REVISION"

In accordance with 10 CFR 50.90, we are enclosing a requested amendment to Licenses DPR-77 and DPR-79 to change the TSs of SQN Units 1 and 2. The proposed change revises the voltage overshoot limits for the D/G during the 18-month, full-load rejection surveillance test performed in accordance with TS 4.8.1.1, 2.d.3. This change will increase the overshoot limit to 8880 volts.

The proposed TS change is identified in Enclosure 1. The justification for the proposed TS change is provided in Enclosure 2. A proposed determination of no significant hazards consideration performed pursuant to 10 CFR 50.92 is provided in Enclosure 3.

TVA requests a 45-day implementation period for this TS change following issuance.

040006

9303040209 930301  
PDR ADOCK 05000327  
P PDR

ADD 11


U.S. Nuclear Regulatory Commission

Page 2

March 1, 1993


Please direct questions concerning this issue to Keith Weller at  
(615) 843-7527.

Sincerely,



Robert A. Fenech

Sworn to and subscribed before me  
this 1 day of March 1993

  
Notary Public  
My Commission Expires 3-9-96

Enclosures

cc (Enclosures):

Mr. D. E. LaBarge, Project Manager  
U.S. Nuclear Regulatory Commission  
One White Flint, North  
11555 Rockville Pike  
Rockville, Maryland 20852-2739

Mr. Michael H. Mobley, Director (w/o Enclosures)  
Division of Radiological Health  
3rd Floor  
L & C Annex  
401 Church Street  
Nashville, Tennessee 37243-1532

NRC Resident Inspector  
Sequoyah Nuclear Plant  
2600 Igou Ferry Road  
Soddy-Daisy, Tennessee 37379-3624

Mr. B. A. Wilson, Project Chief  
U.S. Nuclear Regulatory Commission  
Region II  
101 Marietta Street, NW, Suite 2900  
Atlanta, Georgia 30323-0199