



February 26, 1993

2CAN029307

U. S. Nuclear Regulatory Commission
Document Control Desk
Mail Station P1-137
Washington, DC 20555

Subject: Arkansas Nuclear One - Unit 2
Docket No. 50-368
License No. NPF-6
Annual Diesel Generator Data Report - 1992

Gentlemen:

Arkansas Nuclear One, Unit 2 (ANO-2) Technical Specification 6.9.1.5.d requires an annual submittal of a diesel generator data report for the previous calendar year. This report provides the number of valid tests and the number of valid failures for each diesel generator. The purpose of this letter is to provide this information for 1992.

Twenty six (26) valid tests were conducted on the 2K-4A diesel generator with one (1) valid failure which occurred on April 12, 1992. Thirty three (33) valid tests were conducted on the 2K-4B diesel generator with no valid failures.

This letter completes the reporting requirements for Technical Specification 6.9.1.5.d. Should you have any questions regarding this submittal, please contact me.

Very truly yours,

James J. Fisicaro
Director, Licensing

JJF/SAB/prg

080096

ADD 1/0

cc: Mr. James L. Milhoan
Regional Administrator
U. S. Nuclear Regulatory Commission
Region IV
611 Ryan Plaza Drive, Suite 400
Arlington, TX 76011-8064

NRC Senior Resident Inspector
Arkansas Nuclear One - ANO-1 & 2
Number 1, Nuclear Plant Road
Russellville, AR 72801

Mr. Roby B. Bevan, Jr.
NRR Project Manager, Region IV/ANO-1
U. S. Nuclear Regulatory Commission
NRR Mail Stop 13-H-3
One White Flint North
11555 Rockville Pike
Rockville, Maryland 20852

Mr. Thomas W. Alexion
NRR Project Manager, Region IV/ANO-2
U. S. Nuclear Regulatory Commission
NRR Mail Stop 13-H-3
One White Flint North
11555 Rockville Pike
Rockville, Maryland 20852