

RECEIVED  
NRC  
REGION V

*Southern California Edison Company*

23 PARKER STREET

IRVINE, CALIFORNIA 92718

1993 FEB 24 AM 9:35

WALTER C. MARSH  
ASSISTANT MANAGER  
NUCLEAR REGULATORY AFFAIRS

TELEPHONE  
(714) 454-4403

February 22, 1993

John B. Martin  
Regional Administrator  
U. S. Nuclear Regulatory Commission, Region V  
1450 Maria Lane, Suite 210  
Walnut Creek, CA 94596

Dear Mr. Martin:

Subject: Docket No. 50-362  
Emergency Operations Facility  
San Onofre Nuclear Generating Station, Unit 3

Reference: Letter, R. M. Rosenblum (SCE) to John B. Martin (NRC), EOF  
Ventilation System, September 11, 1992.

In our referenced letter to you dated September 11, 1992, Southern California Edison (SCE) stated that we would install exhaust side isolation dampers to allow isolation of the Emergency Operations Facility (EOF). The purpose of this letter is to inform you that the exhaust dampers have been satisfactorily installed. Subsequent testing has verified that the EOF is now capable of being fully isolated.

In addition to the ventilation upgrade, we committed to conduct a special review of all commitments regarding the EOF. We have completed our review and have confirmed all EOF commitments were completed as originally stated or a functionally equivalent method was used (i.e., a dedicated backup diesel was installed as a second power source in lieu of an additional offsite power source). In summary, we believe we have met the intent of all EOF commitments made in previous correspondence.

If there are any questions, please call me.

Sincerely,

*Walter C. Marsh*

cc: Document Control Desk, NRC  
C. W. Caldwell, NRC Senior Resident Inspector, San Onofre Units 1, 2 & 3  
M. B. Fields, NRC Project Manager, San Onofre Units 2 & 3

08 9303090145 930222  
PDR ADOCK 05000362  
F PDR

1/0  
IE-01