

INDUSTRIAL PRETREATMENT
QUARTERLY SELF-MONITORING RESULTS

Perry Nuclear Power Plant
10 Center Rd.
Perry, Ohio 44081

Permit No.: 1004911
Report Date: 12/21/92
Laboratory: Wadsworth/Alert

Date of Sample: 12/3 to 12/4/92
Sample Location: Sewage Pump Station

Time of sample: 0900
Name of Sampler: Greg Neuman


Laboratory Address: 1401 Shuffel Dr.
North Canton OH 44720

Date of Analysis: 12/4 to 12/17/92
Flow: 46,000 gpm

Name of Analyst: Shery Fazzio

PARAMETER	SAMPLE TYPE	EPA METHOD	ANALYSIS DATE	ANALYSIS RESULT
COD	Composite	410.2	12/16 to 12/17	170 mg/L
BOD	Composite	405.1	12/4 to 12/9	84 mg/L
TSS	Composite	160.2	12/7 to 12/8	330 mg/L
Silver	Composite	200.7	12/6 to 12/15	None Detected
pH	Composite	150.1	12/4	8.4 s.u.

I certify under penalty of law that I have personally examined and I am familiar with the information in this report and that, based on my inquiry of those persons immediately responsible for obtaining the information contained in this report, I believe that the information is true, accurate, and complete. I am aware that there are significant penalties for submitting false information including the possibility of fine and imprisonment.


Signature

3/5/93
Date

Vice President - Nuclear
Title