

INDUSTRIAL PRETREATMENT
QUARTERLY SELF-MONITORING RESULTS

Perry Nuclear Power Plant
10 Center Rd.
Perry, Ohio 44081

Permit No.: 1004911
Report Date: 2/23/93
Laboratory: Wadsworth/Alert

Date of Sample: 2/4 to 2/5/93
Sample Location: Sewage Pump Station

Time of sample: 0925
Name of Sampler: Greg Neuman


Laboratory Address: 1401 Shuffel Dr.
North Canton OH 44720

Date of Analysis: 12/5 to 2/17/93
Flow: 46,000 gpm

Name of Analyst: Shery Fazzio

PARAMETER	SAMPLE TYPE	EPA METHOD	ANALYSIS DATE	ANALYSIS RESULT
COD	Composite	410.2	2/8 to 2/9	300 mg/L
BOD	Composite	405.1	2/5 to 2/10	110 mg/L
TSS	Composite	160.2	2/10/93	88 mg/L
Silver	Composite	200.7	2/17/93	None Detected
pH	Composite	150.1	2/5	8.3 s.u.

I certify under penalty of law that I have personally examined and I am familiar with the information in this report and that, based on my inquiry of those persons immediately responsible for obtaining the information contained in this report, I believe that the information is true, accurate, and complete. I am aware that there are significant penalties for submitting false information including the possibility of fine and imprisonment.

	3/5/93	Vice President - Nuclear
Signature	Date	Title