

# OPERATING DATA REPORT

DOCKET NO. 50-285  
UNIT Fort Calhoun Station  
DATE December 9, 1991  
COMPLETED BY M. L. Edwards  
TELEPHONE (402)636-2451

## OPERATING STATUS

1. Unit Name: Fort Calhoun Station
2. Reporting Period: November 1991
3. Licensed Thermal Power (MWt): 1500
4. Nameplate Rating (Gross MWe): 502
5. Design Electrical Rating (Net MWe): 478
6. Maximum Dependable Capacity (Gross MWe): 502
7. Maximum Dependable Capacity (Net MWe): 478
8. If changes occur in Capacity Ratings (Item Number 3 Through 7) Since Last Report, Give Reasons:  
N/A

Notes

9. Power Level to Which Restricted, If Any (Net MWe): N/A
10. Reasons for Restrictions, If Any: N/A

	This Month	Yr-to-Date	Cumulative
11. Hours in Reporting Period	720.0	8,016.0	159,386.0
12. Number of Hours Reactor Was Critical	720.0	7,286.0	124,074.7
13. Reactor Reserve Shutdown Hours	0.0	0.0	1,309.5
14. Hours Generator On-Line	720.0	7,203.2	122,633.1
15. Unit Reserve Shutdown Hours	0.0	0.0	0.0
16. Gross Thermal Energy Generated (MWH)	1,076,235.2	9,228,594.4	160,512,083.7
17. Gross Electrical Energy Generated (MWH)	366,750.0	3,047,480.0	52,797,606.2
18. Net Electrical Energy Generated (MWH)	350,526.0	2,887,287.2	50,372,063.5
19. Unit Service Factor	100.0	89.9	76.9
20. Unit Availability Factor	100.0	89.9	76.9
21. Unit Capacity Factor (Using MDC Net)	101.8	75.4	68.4
22. Unit Capacity Factor (Using DER Net)	101.8	75.4	66.9
23. Unit Forced Outage Rate	0.0	10.1	3.9
24. Shutdowns Scheduled Over Next 6 Months (Type, Date, and Duration of Each): Refueling outage scheduled to begin February 1, 1992 and last approximately three months.			
25. If Shut Down at End of Report Period, Estimated Date of Startup: N/A			
26. Units In Test Status (Prior to Commercial Operation): Forecast		Achieved	

INITIAL CRITICALITY  
INITIAL ELECTRICITY N/A  
COMMERCIAL OPERATION

Revision 1  
January 29, 1993