

OPERATING DATA REPORT

DOCKET NO. 50-285
UNIT Fort Calhoun Station
DATE January 13, 1992
COMPLETED BY G. R. Cavanaugh
TELEPHONE (402)636-2474

OPERATING STATUS

1. Unit Name: Fort Calhoun Station Notes
2. Reporting Period: December 1991
3. Licensed Thermal Power (MWt): 1500
4. Nameplate Rating (Gross MWe): 502
5. Design Electrical Rating (Net MWe): 478
6. Maximum Dependable Capacity (Gross MWe): 502
7. Maximum Dependable Capacity (Net MWe): 478
8. If changes occur in Capacity Ratings (Item Number 3 Through 7) Since Last Report, Give Reasons:
NA

9. Power Level to Which Restricted, If Any (Net MWe): NA
10. Reasons for Restrictions, If Any: NA

	This Month	Yr-to-Date	Cumulative
11. Hours in Reporting Period	744.0	8,760.0	160,130.0
12. Number of Hours Reactor Was Critical	744.0	8,030.0	124,818.7
13. Reactor Reserve Shutdown Hours	0.0	0.0	1,309.5
14. Hours Generator On-Line	744.0	7,947.2	123,377.1
15. Unit Reserve Shutdown Hours	0.0	0.0	0.0
16. Gross Thermal Energy Generated (MWH)	1,111,552.0	10,340,146.4	161,623,635.7
17. Gross Electrical Energy Generated (MWH)	378,520.0	3,426,000.0	53,176,126.2
18. Net Electrical Energy Generated (MWH)	361,687.9	3,248,975.1	50,733,751.4
19. Unit Service Factor	100.0	90.7	77.0
20. Unit Availability Factor	100.0	90.7	77.0
21. Unit Capacity Factor (Using MDC Net)	101.7	77.6	69.0
22. Unit Capacity Factor (Using DER Net)	101.7	77.6	67.1
23. Unit Forced Outage Rate	0.0	9.3	3.9

24. Shutdowns Scheduled Over Next 6 Months (Type, Date, and Duration of Each):
Refueling outage scheduled for February 1, 1992, and will last approximately three months.
25. If Shut Down at End of Report Period, Estimated Date of Startup: NA
26. Units In Test Status (Prior to Commercial Operation): Forecast NA Achieved

INITIAL CRITICALITY
INITIAL ELECTRICITY N/A
COMMERCIAL OPERATION

Revision 1
January 29, 1993